

LIST OF FIGURES

Figure No.	Caption	Page No.
1.1	Evaluation of phase-to-phase and phase-to earth overvoltages (ref.8),	...6
1.2	Typical switching surge wave shapes (ref. 1),	...7
1.3	Breakdown voltage of rod-plane spark-gap in air, influence of wave shape (ref. 8.),	...7
2.1	50% disruptive discharge voltage U_{50} expressed as a function of time-to-crest T_{cr} for various distances 'd' of a point-plane gap. Results coming from various laboratories (ref. 17).	...28
2.2	Variation of CSOV versus distance: experimental points and estimated curve (ref. 52),	...28
2.3	Effect of ground clearance on flash-over voltage (ref. 46),	...33
2.4	Switching surge sparkover characteristics as a function of the impulse front time (ref. 118),	...33
2.5	Switching impulse bias test results of horizontal rod-rod gaps. 50% flashover voltage $(U^+ + U^-)_{50}$ as a function of α (ref. 87),	...47
2.6	Lightning impulse bias test results for horizontal rod-rod gaps. 50% flashover voltage $(U^+ + U^-)_{50}$ as a function of α (ref.87).	...47
2.7	Investigated longitudinal gap configurations (ref. 87).	...52
2.8	switching impulse bias test results for the circuit breaker simulation. 50% flashover voltage $(U^+ + U^-)_{50}$ as a function of α (ref. 87),	...52

Figure No.	Caption	Page No.
2.9	Positive switching impulse bias test, comparison between circuit-breaker simulation and actual circuit breaker test results. Related 50 % flashover voltage $(U^+ + U^-)_{50}$ $U_{\infty=0}$ as a function of α (ref. 87).	...53
2.10	Lightning impulse bias test, controlled breaker simulation. 50% flashover voltage $(U^+ + U^-)_{50}$ as a function of α (ref.87).	...53
2.11	Effect of humidity on breakdown voltage for different gap spacings (ref. 97).	...62
2.12	Effect of humidity on breakdown voltage for different gap spacings (ref. 97).	...62
3.1	Photograph of damping resistor and grading capacitor.	...77
3.2	Various circuit configurations used to study the severity of the chopped wave on transformer insulation.	...80
3.3	Aerial view of bias test set-up.	...82
3.4	Typical oscillographic records of switching impulse waves at different points of the Bias test circuit for rod-rod gap.	...83
3.5	Typical oscillographic records of lightning impulse voltage wave at different points of the Bias test circuit.	...84
3.6	Typical oscillographic records of AC voltage when flashover occurs across the open gap.	...85
3.7	Typical oscillographic records of SI for open gap flashover.	...86
3.8	Typical oscillographic records of applied voltage U_A (top wave) and voltage drop across the transformer terminal, U_B (Bottom wave).	...89
3.9	Voltage distribution across 500 kV unit as a function of front time of the impulse wave.	...91

Figure No.	Caption	Page No.
3.10	Wave form of transient voltage U_2 on extinction of flashover (ref. 144).	...94
3.11	Typical oscillographic records of impulse and AC wave taken for the measurement of voltage distortion.	...98
3.12	Equivalent circuit of bias test set-up.	...99
3.13	Typical oscillographic records of lightning impulse voltage wave using Haefely make damped Capacitive voltage divider and New divider.	...104
4.1	Circuit layout for the measurement of transferred impulse voltage at terminals 'A' and 'B'.	...113
4.2	Test circuit for conducting bias voltage test.	...116
4.3	Test circuit for conducting bias test on rod-rod gap (ref. 75).	...118
4.4	50% flashover voltage as a function of gap spacing for rod-rod gap electrodes configuration (ref. 75).	...118
4.5	Test circuit for bias test (ref. 81).	...119
4.6	Wave shapes of test voltage-to-ground during phase-to-phase test (ref. 81).	...119
4.7	Circuit arrangement for the tests with bias voltage (ref. 122).	...121
4.8	Impulse bias test circuit used by Hochspannungsfabrik, Oberentfelden (ref. 121).	...122
4.9	Different electrode configurations used for the measurement of voltage drop and U_{50} voltage.	...125
4.10	Variation of transferred impulse voltage $U_B(LI)$ as a function of supporting capacitance C_2127
4.11	Variation of transferred impulse voltage $U_B(LI)$ as a function of damping resistance, $C_1 = 600pF$128

Figure No.	Caption	Page No.
4.12	Variation of transferred impulse voltage U_B (SI) as a function of supporting capacitance, $C_1 = 600\text{pF}$134
4.13	Variation of transferred impulse voltage U_B (SI) as a function of damping resistance, $C_1 = 600\text{pF}$135
4.14	Variation of transferred impulse voltage U_A (SI) as a function of supporting capacitance, $C_1 = 600\text{pF}$136
4.15	Variation of transferred impulse voltage U_A (SI) as a function of damping resistance, $C_1 = 600\text{pF}$138
4.16	Variation of transferred impulse voltage U_B (LI) as a function of supporting capacitance, rod-rod gap,	...140
4.17	Variation of transferred impulse voltage U_B (LI) as a function of damping resistance, rod-rod gap.	...141
4.18	Variation of transferred impulse voltage U_A (LI) as a function of supporting capacitance, rod-rod gap.	...143
4.19	Variation of transferred impulse voltage U_{50} (LI) as a function of damping resistance, rod-rod gap.	...145
4.20	Variation of transferred impulse voltage U_B (SI) as a function of supporting capacitance, rod-rod gap.	...146
4.21	Variation of transferred impulse voltage U_B (SI) as a function of damping resistance, rod-rod gap.	...147
4.22	Variation of transferred impulse voltage U_A (SI) as a function of supporting capacitance, rod-rod gap.	...149

Figure No.	Caption	Page No.
4.23	Variation of transferred impulse voltage U_A (SI) as a function of damping resistance, rod-rod-gap.	...150
5.1	Typical example of 30 shots applied according to the modalities of the 'Up and Down' method (ref. 149).	...158
5.2	Variation of variance co-efficients G and H for the 'Up and Down' method (ref. 149).	...160
5.3	U_{50} (LI) as a function of damping resistance, $C_1 = 600$ pF.	...164
5.4	U_{50} (LI) as a function of damping resistance, $C_1 = 1200$ pF.	...165
5.5	Percentage increase of U_{50} voltage (LI and SI) as a function of damping resistance, $C_1 = 600$ pF.	...166
5.6	U_{50} (SI) as a function of damping resistance, $C_1 = 600$ pF.	...168
5.7	U_{50} (SI) as a function of damping resistance, $C_1 = 1200$ pF.	...169
5.8	U_{50} (LI) as a function of damping resistance, rod-rod gap.	...171
5.9	Percentage increase of U_{50} voltage (LI and SI) for rod-rod gap as a function of damping resistance.	...173
5.10	U_{50} (SI) as a function of damping resistance, rod-rod gap.	...175
5.11	Calculated and measured U_{50} voltage for a capacitive controlled gap, $C_1 = 600$ pF.	...178
5.12	Calculated and measured U_{50} voltage for capacitive controlled gap, $C_1 = 1200$ pF.	...179

Figure No.	Caption	Page No.
5.13	Calculated and measured U_{50} voltage for horizontal rod-rod gap.	...181
5.14	Variation of transferred voltage $U_A(LI)$ as a function of damping resistance, $C_1=600pF$183
5.15	Variation of transferred voltage U_A calculated based on U_{50} as a function of damping resistance, $C_1=600 pF$185
5.16	Variation of transferred voltage $U_A(SI)$ as a function of damping resistance, $C_1=600 pF$187
5.17	Variation of transferred voltage $U_A(LI \text{ and } SI)$ as a function of damping resistance, rod-rod gap.	...189
5.18	Variation of transferred voltage U_A calculated based on U_{50} as a function of damping resistance, rod-rod gap	...190
5.19	Variation of transferred voltage U_B as a function of damping resistance $C_1=600 pF$193
5.20	Percentage variations of transferred voltage U_B as a function of damping resistance, rod-rod gap.	...195
5.21	Circuit layout to study the effect of capacitance C_3 on the flashover voltage U_{50} of the test object.	...205
6.1	Sphere-rod and rod-rod gap assembly.	...216
6.2	Uncorrected U_{50} voltage as a function of humidity for sphere-rod and rod-rod gap under positive switching impulse.	...220
6.3	K_d corrected (U_{SI50}^+) voltage as a function of absolute humidity.	...222

Figure No.	Caption	Page No.
6.4	K_d corrected $(U_{SI}^+ + U_{AC}^-)_{50}$ voltage as a function of absolute humidity.	...223
6.5	IEC corrected $(U_{SI}^+ + U_{AC}^-)_{50}$ voltage as a function of absolute humidity under positive switching impulse voltages.	...225
6.6	Percentage error as a function of absolute humidity when U_{50} is corrected as per IEC publication-60.	...227
6.7	Humidity correction factor K as a function of absolute humidity.	...230
6.8	U_{50} voltage as a function of absolute humidity for sphere-rod and rod-rod gap when opposite terminal is grounded.	...232
6.9	U_{50} voltage as a function of ratio α and U_{AC}^-235
6.10	50 per cent discharge voltage U_{50} expressed as a function of time-to-crest T_{cr} for a rod-rod gap	...237
6.11	Typical oscillographic records of switching impulse waves.	...239
6.12	Results of tests on sphere-rod gap with 250/2600 μ s. waves, U_{50} voltage versus Δt for U_{AC}^- equal to 107.0 kV _p and 215.0 kV _p243
6.13	Results of tests on sphere-rod gap with 250/2600 μ s. waves when peak value of AC voltage and time shift is varied.	...247
A1	Circuit for measurement of self capacitance of transformer.	...280