

# Executive Summary

**ASSESSMENT OF STABILITY OF POWER SYSTEM WITH  
HIGH WIND ENERGY PENETRATION**

By

**JIGNESH P. PATEL**



**DEPARTMENT OF ELECTRICAL ENGINEERING  
FACULTY OF TECHNOLOGY & ENGINEERING  
THE MAHARAJA SAYAJIRAO UNIVERSITY OF BARODA**

**AUGUST, 2020**

# ASSESSMENT OF STABILITY OF POWER SYSTEM WITH HIGH WIND ENERGY PENETRATION

*A Thesis Submitted  
for the Award of the  
Degree of*

**Doctor of Philosophy  
(Electrical Engineering)**

By  
**JIGNESH P. PATEL**



DEPARTMENT OF ELECTRICAL ENGINEERING  
FACULTY OF TECHNOLOGY & ENGINEERING  
THE MAHARAJA SAYAJIRAO UNIVERSITY OF BARODA  
AUGUST, 2020

# Executive Summary Table of Content

Thesis Table of Content	5
Research Methodology	11
Key Findings	12
Conclusion	13
Recommendations/Suggestions	15
Bibliography	16

# Contents

Synopsis	iv
Acknowledgements	xii
<b>1 Introduction</b>	<b>1</b>
1.1 General . . . . .	1
1.2 State of Art . . . . .	3
1.3 Motivation . . . . .	55
1.4 Thesis Structure . . . . .	57
<b>2 Voltage Stability With Wind Power</b>	<b>59</b>
2.1 Introduction . . . . .	59
2.2 Voltage Stability Analysis . . . . .	60
2.2.1 Methods of Voltage Stability Analysis . . . . .	63
2.3 Statistical Estimation Methods for Voltage Stability Evaluation . . . . .	64
2.3.1 Monte Carlo Simulation . . . . .	65
2.3.2 Point Estimation Method . . . . .	66
2.3.2.1 Two Point Estimation Method . . . . .	67
2.3.2.2 Two Point Plus One Sampling ( $2n + 1$ ) Method . . . . .	71
2.3.2.3 Three Point ( $3n$ ) Method . . . . .	71
2.3.2.4 Four Point Plus One Method ( $4n + 1$ ) . . . . .	72
2.3.3 Latin Hypercube Sampling (LHS) . . . . .	74
2.3.4 Method of Series Expansion . . . . .	78
2.3.4.1 Moments and Cumulants . . . . .	79
2.3.4.2 Relation between Cumulants and Moments . . . . .	81
2.3.4.3 PDF Approximation in terms of Reference PDF . . . . .	82

2.3.4.3.1	Exact Solution . . . . .	84
2.3.4.3.2	First Approximation . . . . .	85
2.3.4.3.3	Second Approximation . . . . .	87
2.3.4.4	Gram-Charlier Expansion . . . . .	87
2.3.4.4.1	Selection of Reference PDF . . . . .	88
2.3.4.4.2	Selection Weibull Parameter for Reference PDF . . . . .	89
2.4	Correlated Wind Power Sources . . . . .	89
2.4.1	Relationship Between Correlation Matrix and Covariance Matrix . . . . .	92
2.4.1.1	Conversion of Covariance Matrix to Correlation Matrix . . . . .	93
2.4.1.2	Conversion of Correlation Matrix to Covariance Matrix . . . . .	93
2.5	Results and Discussion . . . . .	95
2.5.1	Simple Method of Voltage Stability with Wind Power Plant . . . . .	95
2.5.1.1	Case-1: Wind Farm Supplying the Load . . . . .	95
2.5.1.2	Case-2: Wind Farm and Grid Supplying the Load . . . . .	100
2.5.2	Voltage Estimation With Wind Power Using Statistical Methods . . . . .	103
2.5.2.1	Analysis of Voltage Variation Estimation of IEEE-12 Bus Radial Network with Wind Power using Statistical Esti- mation Methods . . . . .	104
2.5.2.1.1	Voltage Variation Estimation with Wind Power at Bus-12 . . . . .	105
2.5.2.1.2	Voltage Variation Estimation with Wind Power at Bus-6 . . . . .	114
2.5.2.1.3	Voltage Variation Estimation with Wind Power at Bus-2 . . . . .	124
2.5.2.2	Voltage Estimation of IEEE - 12 Bus Radial System with Multiple Parameter Variation . . . . .	136
2.5.2.3	Voltage Estimation of IEEE - 12 Bus Radial System with Correlated Wind Power Sources at Different Locations . . . . .	147
2.5.3	Probability Function Estimation . . . . .	148
2.6	Conclusion . . . . .	157
<b>3</b>	<b>Harmonic Stability with Wind Power</b>	<b>159</b>
3.1	Introduction . . . . .	159

3.2	Harmonics Resonance . . . . .	161
3.3	Modal Analysis . . . . .	163
	3.3.0.1 Sensitivity of Eigenvalue . . . . .	170
	3.3.1 Relation between Critical Mode and Resonance Frequency . . . . .	172
	3.3.2 Determination of Critical Mode . . . . .	172
	3.3.2.1 Network Aggregation . . . . .	177
3.4	Selection of Method for Harmonic Resonance Analysis . . . . .	178
3.5	Optimization using Simulated Annealing . . . . .	179
	3.5.1 Basic of Simulated Annealing . . . . .	180
	3.5.2 Simulated Annealing Process . . . . .	182
	3.5.3 Cooling Schedule . . . . .	184
	3.5.3.1 Multiplicative Monotonic Cooling . . . . .	185
	3.5.3.1.1 Exponential Monotonic Multiplicative Cooling . . . . .	185
	3.5.3.1.2 Logarithmical multiplicative cooling . . . . .	185
	3.5.3.1.3 Linear multiplicative cooling . . . . .	186
	3.5.3.1.4 Quadratic multiplicative cooling . . . . .	186
	3.5.3.2 Additive Monotonic Cooling . . . . .	187
	3.5.3.2.1 Linear Additive Monotonic cooling . . . . .	187
	3.5.3.2.2 Quadratic Additive Monotonic cooling . . . . .	188
	3.5.3.2.3 Exponential Additive Monotonic cooling . . . . .	188
	3.5.3.2.4 Trigonometric Additive Monotonic cooling . . . . .	188
	3.5.3.3 Non-Monotonic Adaptive Cooling . . . . .	189
	3.5.3.4 Selection of Appropriate Cooling Schedule . . . . .	190
	3.5.3.5 Objective Function Formulation . . . . .	191
3.6	Description of Test Network . . . . .	192
3.7	Results and Discussion . . . . .	195
	3.7.1 Modal Analysis of Wind Farm Connected to Power System . . . . .	195
	3.7.2 Detune Reactor on PF Capacitor . . . . .	203
	3.7.3 Modal Analysis with Detuned Reactor and C-Type Filter on Bus-5 . . . . .	212
	3.7.4 Modal Analysis with Detuned Reactor and High Frequency Filter on Bus-5 . . . . .	218
	3.7.5 Optimization of Harmonic Filter . . . . .	225
	3.7.5.1 Effect of Optimized First Order Filter on Network Impedance . . . . .	233

3.7.5.2	Compliance to IEEE 519 - 1992/2014 Standard . . . . .	241
3.8	Conclusion . . . . .	244
<b>4</b>	<b>Converter Stability Analysis</b>	<b>246</b>
4.1	Introduction . . . . .	246
4.2	Modelling Of Voltage Source Converter . . . . .	247
4.3	Impedance Based Stability Analysis . . . . .	248
4.4	Grid Connected Inverter . . . . .	250
4.5	Phase Lock Loop (PLL) . . . . .	252
4.6	Damped Passive Filter Topologies . . . . .	255
4.6.1	R-L Filter . . . . .	255
4.6.2	L-C Filter . . . . .	258
4.6.3	L-C-L Filter . . . . .	260
4.7	L-C-L Filter Design . . . . .	262
4.8	Results and Discussion . . . . .	263
4.8.1	Passive Damping of Filter . . . . .	263
4.8.1.1	Type-I Filter . . . . .	263
4.8.1.2	Type-II Filter . . . . .	265
4.8.1.3	Type-III Filter . . . . .	267
4.8.1.4	Type-IV Filter . . . . .	269
4.8.1.5	Type-V Filter . . . . .	271
4.8.2	Active Damping of Filter . . . . .	272
4.8.3	System Parameter for Converter Analysis . . . . .	275
4.9	Conclusion . . . . .	275
<b>5</b>	<b>Harmonic Stability of Grid Connected Wind Energy Source - A Case Study</b>	<b>277</b>
5.1	Introduction . . . . .	277
5.2	Network Description . . . . .	278
5.3	Problem Description . . . . .	279
5.4	Methodology . . . . .	280
5.5	State Space Analysis . . . . .	281
5.6	Simulation of Harmonic Resonance of Network . . . . .	287



5.7	Harmonic Filter Design . . . . .	290
5.7.1	Tuned Filter . . . . .	290
5.7.2	C-Type Filter . . . . .	293
5.8	Results and Discussion . . . . .	299
5.9	Conclusion . . . . .	301
<b>6</b>	<b>Small Signal Stability of Doubly Fed Induction Generator</b>	<b>303</b>
6.1	Introduction . . . . .	303
6.2	Modelling of DFIG . . . . .	305
6.2.1	DFIG Equations in a-b-c Form . . . . .	305
6.2.2	$a - b - c$ to $q - d - 0$ Transformation . . . . .	308
6.2.2.1	Transformation Matrix . . . . .	308
6.2.2.2	DFIG Equations in $d - q - 0$ Frame . . . . .	309
6.2.3	State Space Equation Formation . . . . .	310
6.2.4	Electromagnetic Torque . . . . .	312
6.2.5	Drive Train Model . . . . .	314
6.2.5.1	Two Mass Model . . . . .	314
6.2.5.2	One Mass Model . . . . .	316
6.2.6	Converter Model . . . . .	316
6.2.7	Interface of DFIG with Grid . . . . .	322
6.2.7.1	$d - q$ to $D - Q$ Transformation . . . . .	322
6.2.7.2	Power Flow Between DFIG and Grid . . . . .	323
6.2.7.3	DFIG Internal Power Flow . . . . .	324
6.2.8	System Initialization . . . . .	327
6.3	Eigenvalue Analysis . . . . .	330
6.4	Probabilistic Small Signal Stability Analysis . . . . .	331
6.5	System Parameters . . . . .	333
6.6	Results and Discussions . . . . .	333
6.7	Conclusion . . . . .	335
<b>7</b>	<b>Simulation of DFIG with Decoupled Control for Improved LVRT Response</b>	<b>336</b>
7.1	Introduction . . . . .	336

7.2	LVRT Requirements in india . . . . .	337
7.3	Wind Power Model . . . . .	339
7.4	Wind Turbine Model . . . . .	339
7.5	Wind Turbine Inertial Response . . . . .	340
7.6	Pitch Angle Control . . . . .	342
7.7	Decoupled Control Structure . . . . .	344
7.8	Control Scheme . . . . .	345
7.9	Test System . . . . .	351
7.9.1	Test Parameters . . . . .	352
7.10	Simulation Results and Discussion . . . . .	352
7.10.1	Case-A: L-L-G Fault of 250 <i>ms</i> Duration . . . . .	352
7.10.2	Case-B: L-L-G Fault of 1.5 <i>Seconds</i> Duration . . . . .	363
7.11	Conclusion . . . . .	374
<b>8</b>	<b>Conclusion and Future Work</b>	<b>376</b>
8.1	Conclusion . . . . .	376
8.2	Future Work . . . . .	378

# Research Methodology

1. Various issue of stability of power system with wind power from the field is studied and segregated in different types of stability i.e. Voltage Stability, Harmonic Stability, Small Signal Stability
2. The problem related with harmonic stability is studied for understanding the nature of the problem, symptoms, root cause etc. . .
3. The harmonics spectrum of different types of Wind Turbines are studied.
4. Different types of wind farm layout are studied. The sample network is selected for analysis purpose.
5. Different methods of harmonic analysis are studies along with their advantages and disadvantages. The Eigenvalue analysis of modal analysis is selected based on its merits.
6. Using modal analysis the network is analysed and optimized filter is designed. The effectiveness of designed filter is evaluated using actual harmonic spectrum of two different makes of wind turbines.
7. The impact of output filter and structure of PLL is also studied for evaluating its impact on stability of wind turbine.
8. Various statistical methods are compared. Based on the results of comparison, different Point Estimation based methods and Latin Hypercube Sampling methods are selected for carrying out analysis. Also, different PDF (Probability Distribution Function) estimation methods are selected to estimate the voltage PDF.
9. The IEEE standard 12 – Bus Radial network and 39 – Bus system is used to carry out the analysis.
10. The effect of variation of different power system parameters on Doubly Fed Induction Generator is analysed using probabilistic Small Signal Analysis. In this method, the problem of small signal analysis is repeatedly carried out at the selected points. The selected points are decided using the Latin Hypercube Sampling method. Based on the result of analysis, the probability that DFIG remain stable under varying power system parameters are calculated.

# Key Findings

1. The harmonic stability is strongly associated with the strength of the network, at the point where wind turbines are connected, and also on the harmonic spectrum of the Wind Turbine.
2. The harmonic problem can be due to the network incompatibility or due to the inappropriate control structure of the wind turbine.
3. The improvement or degradation in voltage profile depends on the network strength at which the Wind Turbine or Wind Farm is connected.
4. The two point estimation is very effective as compared to other point estimation methods. Similarly, the Latin Hyper Cube Sampling (median) is better than the Latin Hyper Cube Sampling (random). Further, the Latin Hypercube Sampling method is grossly effective in simplicity and accuracy.
5. The fourth order PDF approximation method gives better and consistent error as compared to other methods of PDF approximation.
6. The structure of controller of Wind Turbine is very critical from stability point of view.
7. The deterministic method of small signal stability is not sufficient and probabilistic method are better for predicting the stability of wind turbine under different operating conditions.
8. Grid code compliance can be achieved with properly selected decoupled controller structure and controller parameters.
9. Negatively correlated wind sources are effective in maintaining the stable voltage profile

# Conclusion

In this work, the three aspects of stability; voltage stability, harmonic stability and small signal stability, is analysed. The different cases are studied and results are evaluated in depth. The gist of all results and conclusion are given here. The steady state voltage stability is an important aspects of power system with renewable energy sources. The probabilistic approach should be followed, during the planning stage and also during routine unit commitment, to put check on the voltage instability.

As the renewable energy will contribute more and more in future, the voltage instability is likely to creep in to the system and may affect the whole power system. In this work, from simple approach for single system to complex approach using statistical estimation methods are given. Different statistical approaches are compared and the balanced approach has been suggested for practical use. The point estimation is used to reduce the computational burden and still holding accuracy. This approach is sampling based and applied before core analysis. The problem with point estimation is that, it requires large data to compute the cummulants and moments. Also, this method doesn't guarantee the stability with increased number of variables. Also, with multipoint estimation, the accuracy should get improved, but it is found that accuracy is negatively affected. In this regard, the Latin Hypercube Sampling approach is very balance. This method gives very accurate first moment ( $\mu$ ) and very consistent second moment ( $\sigma$ ). The error in calculation in second moment is on the higher side as compared to point estimation, but it is still satisfying as the result shows consistency of 12 % to 15 % in error. The important point, which should be kept in mind is that, the data points required for point estimation is 1000, whereas the LHS requires very few samples (10 samples). In probability estimation, various methods like gram - charlier expansion, exact series expansion and several approximation is examined for accuracy. It is found that second approximation works well and gives good consistency. The gram charlier expansion is very conservation and overlooks the accuracy to uphold the stability or series convergence. The estimation and series expansion method can be used in combination to achieve the best result. The LHS and Second Approximation (SA) is good combination, which can estimate non-normal variable accurately with small sample size.

The variability of wind power definitely induce the variability in voltages at various buses. The higher the share of uncertain sources, larger will be the variability. Also, it is found that the variability in voltage gets affected by the correlation between different wind sources. Negatively correlated wind sources helps in maintaining the voltage stability. Also, the system strength (short circuit capacity) affects the voltage stability. The placement of wind sources also plays important role in determining the voltage stability. The wind sources shall be placed in the system, where the system strength is high. The second important aspect, which studied in

this work, is harmonic stability. The harmonic stability is a derived word and it is not found in any literature so far studied. The reason behind using this word is to imply that the stability of power system gets affected by harmonic level in the power system. The new technologies of wind turbines are mostly based on power electronic converters. The power electronic converters generate harmonics. As the number of WTGs in power system is increasing, the harmonic level definitely get affected. And first, it will affect the individual WTG and consequentially the entire power system will get affected. Traditionally, harmonic problems are related with the power quality. But, in this work, it is related with stability.

To study the harmonic stability and find optimal solution, different methods are studied and modal analysis is selected based on merits, mainly considering its simplicity and effectiveness. Till now, the modal analysis has been applied for determination of harmonic resonance only. However, in this work, it is taken further for determining the root cause of harmonic resonance and designing the optimal solution.

Different WTGs have, different harmonic spectrum. So, any WTG cannot be connected at any location in the power system. The system strength and harmonic spectrum of WTG shall be checked before placement of any WTG. Using actual spectrum of two different WTG, it is explained that, how one WTG is suitable and another is not for connecting to a given location.

The third and important aspect studied in this work is small signal stability. The Small signal stability of WTG gets affected by different parameters of power system and it is studied using probabilistic approach. The single point small signal stability of WTG is not useful with uncertain wind and many other variables in power system. On the other side, multipoint small signal stability requires many computation and hence will be time consuming and shall not be appropriate for many optimization techniques. The balance can be achieved by using probabilistic analysis. The proposed method based on LHS is less computational intensive and can be used for fast evaluation of stability. It is demonstrated that the variation in different parameters may affect the small signal stability of WTG. It is difficult to predict the stability with single point calculation. Here, the simple and effective way of analysis has been given to carry out probabilistic small signal stability analysis.

Finally, the simulation is carried out using EMTP to show the compliance to grid code related to LVRT. In this simulation it is shown that, the decoupled control is effective in successful in riding through of fault.

# Suggestions/Recommendations

1. Single point stability is not appropriate for hybrid power system. Probabilistic/Stochastic analysis is more appropriate for variable wind power stability analysis.
2. Probabilistic stability analysis should be carried out at the planning stage of wind power to avoid issues later in operation stage.
3. Wind Turbine Generator (WTG) should be selected with minimum possible harmonic emission.
4. The WTG should be placed in the network where the strength of network is high.
5. Any WTG cannot be connected at any location in the power system. The system strength and harmonic spectrum of WTG shall be checked before placement of any WTG.
6. The reactive power planning is very important for ascertaining the voltage stability of power system with high penetration of wind power.
7. LHS based probabilistic analysis should be used for fast evaluation of stability of wind power based power system.
8. The grid code compliance shall be checked at the system planning stage so that suitable WTG can be selected.
9. The control structure is traditionally selected based on the small signal stability analysis. However, the harmonic stability is also important and shall be considered while selecting control structure and control parameters.
10. The output filter of WTG is also important and shall be selected based on the harmonic stability analysis.

# Bibliography

- [1] Analytic, “Latin hypercube vs. monte carlo sampling,” <https://lumina.com/latin-hypercube-vs-monte-carlo-sampling/>.
- [2] J. Slootweg and W. Kling, “The impact of large scale wind power generation on power system oscillations,” *Electric Power Systems Research*, vol. 67, 2003.
- [3] D. S. Brereton and C. C. Lewis, D. G. and Young, “Representation of induction-motor loads during power-system stability studies,” *Transactions of the American Institute of Electrical Engineers Part III Power Apparatus and Systems*, vol. 76, 1957.
- [4] M. EL-Shimy, M. Badr, and O. Rassem, “Impact of large scale wind power on power system stability,” in *IEEE-2008, 12th International Middle East Power System Conference - MEPCON - Aswan, Egypt (2008.03.12-2008.03.15)*, 2008.
- [5] G. L. Johnson, *Wind Energy Systems*, 1st ed. Prentice Hall, 1985.
- [6] A. Pinto, B. Carvalho, J. Oliveira, G. Guimaraes, A. Moraes, C. Salerno, and Z. Vitorio, “Analysis of a wecs connected to utility grid with synchronous generator,” in *IEEE 2006 IEEE/PES Transmission & Distribution Conference and Exposition: Latin America - Caracas, Venezuela (2006.08.15-2006.08.18)*, 2006.
- [7] P. Kundur, *Power System Stability and Control*. McGraw-Hill Professional, 1994.
- [8] E. Vittal, M. O’Malley, and A. Keane, “A steady-state voltage stability analysis of power systems with high penetrations of wind,” *IEEE Transactions on Power Systems*, vol. 25, 2010.



- [9] R. Billinton and W. Wangdee, "Reliability-based transmission reinforcement planning associated with large-scale wind farms," *IEEE Transactions on Power Systems*, vol. 22, 2007.
- [10] R. Billinton, H. Chen, and R. Ghajar, "A sequential simulation technique for adequacy evaluation of generating systems including wind energy," *IEEE Transactions on Energy Conversion*, vol. 11, 1996.
- [11] M. J. Burke, D. J. and O'Malley, "Optimal wind power location on transmission systema probabilistic load flowapproach," in *Proc. Int. Conf. Probabilistic Methods Applied to Power System, 2008*, 2008.
- [12] A. Bakirtzis, P. Dokopoulos, E. Gavanidou, and M. Ketselides, "A probabilistic costing method for the evaluation of the performance of grid-connected wind arrays," *IEEE Transactions on Energy Conversion*, vol. 4, 3 1989.
- [13] N. Hatziaargyriou, T. Karakatsanis, and M. Papadopoulos, "Probabilistic load flow in distribution systems containing dispersed wind power generation," *IEEE Transactions on Power Systems*, vol. 8, 1993.
- [14] T. Boehme, A. Wallace, and G. Harrison, "Applying time series to power flow analysis in networks with high wind penetration," *IEEE Transactions on Power Systems*, vol. 22, 2007. [Online]. Available: <https://ieeexplore.ieee.org/document/4282010>
- [15] D. Infield and M. Thomson, "Network power flow analysis for a high penetration of distributed generation," *IEEE Transactions on Power Systems*, vol. 22, 2007. [Online]. Available: <https://ieeexplore.ieee.org/document/1709489>
- [16] T. Ackermann, *Wind Power in Power Systems (Ackermann/Wind Power in Power Systems)-Maximizing Renewable Generation on the Power System of Ireland and Northern Ireland*, 2012, vol. 10.1002/9781119941842.
- [17] H. Wan, J. McCalley, and V. Vittal, "Risk based voltage security assessment," *IEEE Transactions on Power Systems*, vol. 15, 2000.
- [18] Y. Vaahedi, E. and Mansour, C. Fuchs, S. Granville, M. Latore, and H. Hamadanizadeh, "Dynamic security constrained optimal power flow/var planning," *IEEE Transactions on Power Systems*, vol. 16, 2001.

- [19] M. Bakhtvar and A. Keane, "Optimal allocation of wind generation subject to voltage stability constraints," 2013.
- [20] H. Song, B. Lee, S.-H. Kwon, and V. Ajjarapu, "Reactive reserve-based contingency constrained optimal power flow (rccopf) for enhancement of voltage stability margins," *IEEE Transactions on Power Systems*, vol. 18, 2003.
- [21] "Voltage stability constrained optimal power flow (vscopf) with two sets of variables (tsv) for reactive power planning," in *IEEE/PES Transmission and Distribution Conference and Exposition, Chicago, IL, USA (2008.04.21-2008.04.24)*.
- [22] R. Zarate-Mihano, A. Conejo, and F. Milano, "Opf-based security redispatching including facts devices," *IET Generation Transmission & Distribution*, vol. 2, 2008.
- [23] D. Burke and M. O'Malley, "Maximizing firm wind connection to security constrained transmission networks," *IEEE Transactions on Power Systems*, vol. 25, 2010.
- [24] M. Nick, G. Riahy, S. Hosseini, and F. Fallahi, "Wind power optimal capacity allocation to remote areas taking into account transmission connection requirements," *IET Renewable Power Generation*, vol. 5, 2011.
- [25] Y. Gu, J. D. McCalley, and M. Ni, "Coordinating large-scale wind integration and transmission planning," *IEEE Transactions on Sustainable Energy*, vol. 3, 10 2012.
- [26] R. S. Al Abri, E. F. El-Saadany, and Y. M. Atwa, "Optimal placement and sizing method to improve the voltage stability margin in a distribution system using distributed generation," *IEEE Transactions on Power Systems*, vol. 28, 02 2013.
- [27] M. Bakhtvar and A. Keane, "Allocation of wind capacity subject to long term voltage stability constraints," *IEEE Transactions on Power Systems*, 2015.
- [28] S. Burchett, D. Douglas, S. G. Ghiocel, M. Liehr, J. H. Chow, D. Kosterev, A. Faris, E. Heredia, and G. H. Matthews, "An optimal thvenin equivalent estimation method and its application to the voltage stability analysis of a wind hub," *IEEE Transactions on Power Systems*, 2017.

- [29] S. Chun-Lien, "Stochastic evaluation of voltages in distribution networks with distributed generation using detailed distribution operation models," *IEEE Transactions on Power Systems*, vol. 25, 2010.
- [30] J. Zhang, C. Tse, K. Wang, and C. Chung, "Voltage stability analysis considering the uncertainties of dynamic load parameters," *IET Generation Transmission & Distribution*, vol. 3, 2009.
- [31] D. Jia, L. Hu, K.-y. Liu, Y. Liu, X. Meng, and W. Sheng, "Simplified probabilistic voltage stability evaluation considering variable renewable distributed generation in distribution systems," *IET Generation Transmission & Distribution*, vol. 9, 09 2015.
- [32] S. G. Ghiocel and J. H. Chow, "A power flow method using a new bus type for computing steady-state voltage stability margins," *IEEE Transactions on Power Systems*, vol. 29, 03 2014.
- [33] F. Mohn and A. Zambroni De Souza, "Tracing pv and qv curves with the help of a cric continuation method," *IEEE Transactions on Power Systems*, vol. 21, 08 2006.
- [34] K. Lo, E. V. De Lorenci, B. I. L. Lopes, A. B. Almeida, A. C. Zambroni de Souza de Souza, and R. C. Leme, "Probabilistic voltage stability assessment considering renewable sources with the help of the pv and qv curves," *IET Renewable Power Generation*, vol. 7, 09 2013.
- [35] M. Pipattanasomporn, M. Willingham, and S. Rahman, "Implications of on-site distributed generation for commercial/industrial facilities," *IEEE Transactions on Power Systems*, vol. 20, 2005.
- [36] M. Fahrioglu, R. H. Lasseter, F. L. Alvarado, and T. Yong, "Integrating distributed generation technology into demand management schemes," in *IEEE-PES/IAS Conference on Sustainable Alternative Energy (SAE) - Valencia, Spain (2009.09.28-2009.09.30)*, 2009.

- [37] M. Pipattanasomporn and S. Rahman, "Intelligent distributed autonomous power systems (idaps) and their impact on critical electrical loads," in *First IEEE International Workshop on Critical Infrastructure Protection (IWCIP'05) - Darmstadt, Germany (03-04 Nov. 2005)*, 2005.
- [38] L. Ochoa, A. Padilha-Feltrin, and G. Harrison, "Time-series-based maximization of distributed wind power generation integration," *IEEE Transactions on Energy Conversion*, vol. 23, 2008.
- [39] K. Nara, Y. Hayashi, K. Ikeda, and T. Ashizawa, "Application of tabu search to optimal placement of distributed generators," in *IEEE-2001 Winter Meeting of the IEEE Power Engineering Society, Conference Proceedings (Cat. No.01CH37194), Columbus, OH, USA (28 Jan.-1 Feb. 2001)*, vol. 2, 2001.
- [40] M. Golshan and S. Arefifar, "Distributed generation, reactive sources and network-configuration planning for power and energy-loss reduction," *IEE Proceedings - Generation Transmission and Distribution*, vol. 153, 2006.
- [41] D. Singh and K. Verma, "Multiobjective optimization for dg planning with load models," *IEEE Transactions on Power Systems*, vol. 24, 2009.
- [42] G. P. Harrison, A. Piccolo, P. Siano, and A. R. Wallace, "Distributed generation capacity evaluation using combined genetic algorithm and opf," *International Journal of Emerging Electric Power Systems*, vol. 8, 01 2007.
- [43] C. L. Borges and D. M. Falco, "Optimal distributed generation allocation for reliability, losses, and voltage improvement," *International Journal of Electrical Power & Energy Systems*, vol. 28, 2006.
- [44] S. Grady, M. Hussaini, and M. Abdullah, "Placement of wind turbines using genetic algorithms," *Renewable Energy*, vol. 30, 2005.
- [45] G. Celli, E. Ghiani, S. Mocci, and F. Pilo, "A multiobjective evolutionary algorithm for the sizing and siting of distributed generation," *IEEE Transactions on Power Systems*, vol. 20, 05 2005.

- [46] G. Carpinelli, G. Celli, S. Mocci, F. Pilo, and A. Russo, "Optimisation of embedded generation sizing and siting by using a double trade-off method," *IEE Proceedings - Generation Transmission and Distribution*, vol. 152, 2005.
- [47] D. Popovic, J. Greatbanks, M. Begovic, and A. Pregelj, "Placement of distributed generators and reclosers for distribution network security and reliability," *International Journal of Electrical Power & Energy Systems*, vol. 27, 2005.
- [48] N. Rau and Y.-H. Wan, "Optimum location of resources in distributed planning," *IEEE Transactions on Power Systems*, vol. 9, 1994.
- [49] K. Vinoth Kumar and M. Selvan, "Placement of distributed generators and reclosers for distribution network security and reliability," *Aust. J. Electr. Electron. Eng.*, vol. 8, 2011.
- [50] K. Vinothkumar and M. P. Selvan, "Fuzzy embedded genetic algorithm method for distributed generation planning," *Electric Power Components and Systems*, vol. 39, 02 2011.
- [51] H. Hedayati, S. Nabaviniaki, and A. Akbarimajd, "A method for placement of dg units in distribution networks," *IEEE Transactions on Power Delivery*, vol. 23, 2008.
- [52] K. Vinothkumar, "Investigations on distributed generation planning and certain grid interaction issues of wind turbine generation system," Ph.D. dissertation, National Institute of Technology, Tiruchirappalli, NIT, Tiruchirappalli, 4 2011.
- [53] Kumaresan and Subbiah, "Innovative reactive power saving in wind-driven grid-connected induction generators using a deltastar stator winding; part i," *Wind Engineering*, vol. 27, 05 2003.
- [54] Subbiah and Kumaresan, "Innovative reactive power saving in wind-driven grid-connected induction generators using a delta-star stator winding: Part ii, estimation of annual wh and varh of the delta-star generator and comparison with alternative schemes," *Wind Engineering*, vol. 27, 05 2003.

- [55] P. Raja, N. Kumaresan, and M. Subbiah, "Grid-connected induction generators using delta-star switching of the stator winding with a permanently connected capacitor," *Wind Engineering*, vol. 36, 04 2012.
- [56] P. Raja, M. P. Selvan, and N. Kumaresan, "Enhancement of voltage stability margin in radial distribution system with squirrel cage induction generator based distributed generators," *IET Generation Transmission & Distribution*, vol. 7, 08 2013.
- [57] M. Donnelly, J. Dagle, D. Trudnowski, and G. Rogers, "Impacts of the distributed utility on transmission system stability," *IEEE Transactions on Power Systems*, vol. 11, 5 1996.
- [58] R. Guttromson, "Modeling distributed energy resource dynamics on the transmission system," *IEEE Transactions on Power Systems*, vol. 17, 2002.
- [59] M. Reza, J. Slootweg, P. Schavernaker, and L. van der Sluis, "Investigating impacts of distributed generation on transmission system stability," in *IEEE Bologna Power Tech Conference Proceedings - Bologna, Italy (June 23-26, 2003)*, vol. 2, 2003.
- [60] Committee-38, "Modeling new forms of generation and storage," *CIGRE TF*.
- [61] V. Thong, D. Van Dommelen, J. Driesen, and R. Belmans, "Impact of large scale distributed and unpredictable generation on voltage and angle stability of transmission system," in *40<sup>th</sup> CIGRE Conf., article C6205, Paris, France, August 29-September 3, 2004*, 2004.
- [62] G. Huang and L. Zhao, "Measurement based voltage stability monitoring of power system." [Online]. Available: [www.pserc.wisc.edu](http://www.pserc.wisc.edu).
- [63] V. Costas, *Voltage Stability of Electric Power Systems*, ser. The Kluwer international series in engineering and computer science Power electronics and power systems 441. Kluwer Academic Publishers, 1998.
- [64] "Voltage stability assessment: Concepts, practices and tools," Tech. Rep.
- [65] A. Leite da Silva, I. Coutinho, A. Zambroni de Souza, R. Prada, and A. Rei, "Voltage collapse risk assessment," *Electric Power Systems Research*, vol. 54, 2000.

- [66] A. Rodrigues, R. Prada, and M. Da Guia da Silva, "Voltage stability probabilistic assessment in composite systems: Modeling unsolvability and controllability loss," *IEEE Transactions on Power Systems*, vol. 25, 2010.
- [67] C. Su and C. Lu, "Two-point estimate method for quantifying transfer capability uncertainty," *IEEE Transactions on Power Systems*, vol. 20, 05 2005.
- [68] J. Munoz, C. Canizares, K. Bhattacharya, and A. Vaccaro, "An affine arithmetic-based method for voltage stability assessment of power systems with intermittent generation sources," *IEEE Transactions on Power Systems*, vol. 28, 11 2013.
- [69] A. Vaccaro, C. A. Canizares, and D. Villacci, "An affine arithmetic-based methodology for reliable power flow analysis in the presence of data uncertainty," *IEEE Transactions on Power Systems*, vol. 25, 05 2010.
- [70] R. Jabr and B. Pal, "Ordinal optimisation approach for locating and sizing of distributed generation," *IET Generation Transmission & Distribution*, vol. 3, 2009.
- [71] A. Kumar and W. Gao, "Optimal distributed generation location using mixed integer non-linear programming in hybrid electricity markets," *IET Generation Transmission & Distribution*, vol. 4, 2010.
- [72] F. Abu-Mouti and M. El-Hawary, "Heuristic curve-fitted technique for distributed generation optimisation in radial distribution feeder systems," *IET Generation Transmission & Distribution*, vol. 5, 2011.
- [73] M. Akorede, H. Hizam, I. Aris, and M. Ab Kadir, "Effective method for optimal allocation of distributed generation units in meshed electric power systems," *IET Generation Transmission & Distribution*, vol. 5, 2011.
- [74] A. El-Zonkoly, "Optimal placement of multi-distributed generation units including different load models using particle swarm optimisation," *IET Generation Transmission & Distribution*, vol. 5, 2011.
- [75] P. S. Georgilakis and N. D. Hatziargyriou, "Optimal distributed generation placement in power distribution networks: Models, methods, and future research," *IEEE Transactions on Power Systems*, vol. 28, 08 2013.

- [76] M.-R. Haghifam, H. Falaghi, and O. Malik, "Risk-based distributed generation placement," *IET Generation Transmission & Distribution*, vol. 2, 2008.
- [77] G. Carpinelli, G. Celli, F. Pilo, and A. Russo, "Embedded generation planning under uncertainty including power quality issues," *European Transactions on Electrical Power*, vol. 13, 2003.
- [78] E. Haesen, J. Driesen, and R. Belmans, "Robust planning methodology for integration of stochastic generators in distribution grids," *IET Renewable Power Generation*, vol. 1, 2007.
- [79] Z. Liu, F. Wen, and G. Ledwich, "Optimal siting and sizing of distributed generators in distribution systems considering uncertainties," *IEEE Transactions on Power Delivery*, vol. 26, 2011.
- [80] K. Zou, A. Agalgaonkar, K. Muttaqi, and S. Perera, "Distribution system planning with incorporating dg reactive capability and system uncertainties," *IEEE Transactions on Sustainable Energy*, vol. 3, 2012.
- [81] M. Mokhtari fard, R. Noroozian, and S. Molaei, "Determining the optimal placement and capacity of dg in intelligent distribution networks under uncertainty demands by coa," in *Iranian Conference on Smart Grids*, 2012, pp. 1–8.
- [82] F. Ugranli and E. Karatepe, "Multiple-distributed generation planning under load uncertainty and different penetration levels," *International Journal of Electrical Power & Energy Systems*, vol. 46, 3 2013.
- [83] V. A. Evangelopoulos and P. S. Georgilakis, "Optimal distributed generation placement under uncertainties based on point estimate method embedded genetic algorithm," *IET Generation Transmission & Distribution*, 03 2014.
- [84] Y. Atwa, E. El-Saadany, M. Salama, and R. Seethapathy, "Optimal renewable resources mix for distribution system energy loss minimization," *IEEE Transactions on Power Systems*, vol. 25, 2010.
- [85] J. Kim, S. Nam, S. Park, and C. Singh, "Dispersed generation planning using improved hereford ranch algorithm," *Electric Power Systems Research*, vol. 47, 1998.



- [86] M. Gandomkar, M. Vakilian, and M. Ehsan, "Optimal distributed generation allocation in distribution network using hereford ranch algorithm," in *IEEE Proceedings of the Eighth International Conference on Electrical Machines and Systems - Nanjing, China (2005.09.29-2005.09.29)*, 2005.
- [87] T. Griffin, K. Tomsovic, D. Secrest, and A. Law, "Placement of dispersed generation systems for reduced losses," in *Proceedings of the 33rd Annual Hawaii International Conference on System Sciences, IEEE Comput. Soc HICSS33, Maui, HI, USA (4-7 Jan. 2000)*, vol. 1, 2000.
- [88] J. Greatbanks, D. Popovic, M. Begovic, A. Pregelj, and T. Green, "On optimization for security and reliability of power systems with distributed generation," in *IEEE Bologna Power Tech Conference Proceedings- Bologna, Italy (June 23-26, 2003)*, vol. 1, 2003.
- [89] P. Vovos, G. Harrison, and J. Wallace, A.and Bialek, "Optimal power flow as a tool for fault level-constrained network capacity analysis," *IEEE Transactions on Power Systems*, vol. 20, 2005.
- [90] V. Quezada, J. Abbad, and T. Roman, "Assessment of energy distribution losses for increasing penetration of distributed generation," *IEEE Transactions on Power Systems*, vol. 21, 2006.
- [91] C. Wang and M. Nehrir, "Analytical approaches for optimal placement of distributed generation sources in power systems," *IEEE Transactions on Power Systems*, vol. 19, 11 2004.
- [92] G. Celli and F. Pilo, "Optimal distributed generation allocation in mv distribution networks," in *IEEE 2001 Power Industry Computer Applications Conference - Sydney, NSW, Australia (20-24 May 2001)*, 2001.
- [93] F. Pilo and G. Celli, "Mv network planning under uncertainties on distributed generation penetration," in *IEEE Power Engineering Society Summer Meeting - Vancouver, BC, Canada (15-19 July 2001)*, vol. 1, 2001.
- [94] N. Saad, M. Sujod, M. F. Abas, M. H. Sulaiman, and M. Rashid, "Optimal placement and sizing of distributed generation based on mvmo-sh," 01 2019.

- [95] “Maximisation of intermittent distributed generation in active networks,” in *IEE CIRED Seminar 2008: SmartGrids for Distribution - Frankfurt, Germany (23-24 June 2008)*.
- [96] W. El-Khattam, K. Bhattacharya, Y. Hegazy, and M. Salama, “Optimal investment planning for distributed generation in a competitive electricity market,” *IEEE Transactions on Power Systems*, vol. 19, 2004.
- [97] W. El-Khattam, Y. Hegazy, and M. Salama, “An integrated distributed generation optimization model for distribution system planning,” *IEEE Transactions on Power Systems*, vol. 20, 2005.
- [98] T. Gozel and M. Hakan Hocaoglu, “An analytical method for the sizing and siting of distributed generators in radial systems,” *Electric Power Systems Research*, vol. 79, 2009.
- [99] A. Piccolo and P. Siano, “Evaluating the impact of network investment deferral on distributed generation expansion,” *IEEE Transactions on Power Systems*, vol. 24, 2009.
- [100] P. Reche Lopez, M. Gomez Gonzalez, N. Ruiz Reyes, and F. Jurado, “Optimization of biomass fuelled systems for distributed power generation using particle swarm optimization,” *Electric Power Systems Research*, vol. 78, 2008.
- [101] E. Haesen, C. Bastiaensen, J. Driesen, and R. Belmans, “A probabilistic formulation of load margins in power systems with stochastic generation,” *IEEE Transactions on Power Systems*, vol. 24, 2009.
- [102] F. Zhihong, V. Ajjarapu, and D. Maratukulam, “A comprehensive approach for preventive and corrective control to mitigate voltage collapse,” *IEEE Transactions on Power Systems*, vol. 15, 2000.
- [103] Z. Feng and W. Xu, “Fast computation of post-contingency system margins for voltage stability assessments of large-scale power systems,” *IEE Proceedings - Generation Transmission and Distribution*, vol. 147, 2000.
- [104] I. Dobson and L. Lu, “Computing an optimum direction in control space to avoid stable node bifurcation and voltage collapse in electric power systems,”

- IEEE Transactions on Automatic Control*, vol. 37, 1992. [Online]. Available: <https://ieeexplore.ieee.org/document/256397>
- [105] C. Canizares, "Calculating optimal system parameters to maximize the distance to saddle-node bifurcations," *IEEE Transactions on Circuits and Systems I Fundamental Theory and Applications*, vol. 45, 1998.
- [106] C. Chung, T. Chung, C. Yu, and X. Lin, "Cost-based reactive power pricing with voltage security consideration in restructured power systems," *Electric Power Systems Research*, vol. 70, 2004.
- [107] A. David and R. Fang, "Security-based rescheduling of transactions in a deregulated power system," *IEE Proceedings - Generation Transmission and Distribution*, vol. 146, 1999.
- [108] S. Hao and A. Papalexopoulos, "Reactive power pricing and management," *IEEE Transactions on Power Systems*, vol. 12, Feb 1997.
- [109] X. Lin, A. David, and C. Yu, "Reactive power optimisation with voltage stability consideration in power market systems," *IEE Proceedings - Generation Transmission and Distribution*, vol. 150, 2003.
- [110] F. Dong, B. Chowdhury, M. Crow, and L. Acar, "Improving voltage stability by reactive power reserve management," *IEEE Transactions on Power Systems*, vol. 20, 02 2005.
- [111] K. Shubhanga and A. Kulkarni, "Stability-constrained generation rescheduling using energy margin sensitivities," *IEEE Transactions on Power Systems*, vol. 19, 2004.
- [112] C. Chung, L. Wang, F. Howell, and P. Kundur, "Generation rescheduling methods to improve power transfer capability constrained by small-signal stability," *IEEE Transactions on Power Systems*, vol. 19, 02 2004.
- [113] F. Capitanescu and T. Van Cutsem, "Preventive control of voltage security margins: a multicontingency sensitivity-based approach," *IEEE Transactions on Power Systems*, vol. 17, 2002.

- [114] G. Wu, C. Chung, K. Wong, and C. Yu, "Voltage stability constrained optimal dispatch in deregulated power systems," *IET Generation Transmission & Distribution*, vol. 1, 2007.
- [115] S. Muller, M. Deicke, and R. De Doncker, "Doubly fed induction generator systems for wind turbines," *IEEE Industry Applications Magazine*, vol. 8, 2002.
- [116] A. Petersson, L. Harnefors, and T. Thiringer, "Evaluation of current control methods for wind turbines using doubly-fed induction machines," *IEEE Transactions on Power Electronics*, vol. 20, 2005.
- [117] G. Pannell, D. Atkinson, R. Kemsley, L. Holdsworth, P. Taylor, and O. Moja, "Dfig control performance under fault conditions for offshore wind applications," in *IEE 18th International Conference and Exhibition on Electricity Distribution (CIRED 2005) - Turin, Italy (6-9 June 2005)*, vol. 2005, 2005.
- [118] D. Xiang, L. Ran, P. J. Tavner, and J. R. Bumby, "Control of a doubly fed induction generator to ride through a grid fault," in *Int. Conf. Electric Machines (ICEM), Cracow, Poland*.
- [119] N. Kirby, L. Xu, M. Luckett, and W. Siepmann, "Hvdc transmission for large offshore wind farms," *Power Engineering Journal*, vol. 16, 2002.
- [120] X. Dawei, R. Li, P. Tavner, and S. Yang, "Control of a doubly fed induction generator in a wind turbine during grid fault ride-through," *IEEE Transactions on Energy Conversion*, vol. 21, 2006.
- [121] A. Kasem, E. El-Saadany, H. El-Tamaly, and M. Wahab, "Power ramp rate control and flicker mitigation for directly grid connected wind turbines," *IET Renewable Power Generation*, vol. 4, 2010.
- [122] H. Jinwei and W. L. Yun, "Generalized closed-loop control schemes with embedded virtual impedances for voltage source converters with lc or lcl filters," *IEEE Transactions on Power Electronics*, vol. 27, 2012.
- [123] S. Vesti, T. Suntio, J. A. Oliver, R. Prieto, and J. A. Cobos, "Impedance-based stability and transient-performance assessment applying maximum peak criteria," *IEEE Transactions on Power Electronics*, vol. 28, 05 2013.

- [124] L. Zhang, L. Harnefors, and H.-P. Nee, "Interconnection of two very weak ac systems by vsc-hvdc links using power-synchronization control," *IEEE Transactions on Power Systems*, vol. 26, 2011.
- [125] J. Sun, "Impedance-based stability criterion for grid-connected inverters," *IEEE Transactions on Power Electronics*, vol. 26, 11 2011.
- [126] J. He, Y. W. Li, D. Bosnjak, and B. Harris, "Investigation and active damping of multiple resonances in a parallel-inverter-based microgrid," *IEEE Transactions on Power Electronics*, vol. 28, 01 2013.
- [127] J. Z. Zhou, H. Ding, S. Fan, Y. Zhang, and A. M. Gole, "Impact of short-circuit ratio and phase-locked-loop parameters on the small-signal behavior of a vsc-hvdc converter," *IEEE Transactions on Power Delivery*, vol. 29, 10 2014.
- [128] X. Wang, F. Blaabjerg, M. Liserre, Z. Chen, J. He, and Y. Li, "An active damper for stabilizing power-electronics-based ac systems," *IEEE Transactions on Power Electronics*, vol. 29, 07 2014.
- [129] D. Yang, X. Ruan, and H. Wu, "Impedance shaping of the grid-connected inverter with lcl filter to improve its adaptability to the weak grid condition," *IEEE Transactions on Power Electronics*, vol. 29, 11 2014.
- [130] D. Dong, B. Wen, D. Boroyevich, P. Mattavelli, and Y. Xue, "Analysis of phase-locked loop low-frequency stability in three-phase grid-connected power converters considering impedance interactions," *IEEE Transactions on Industrial Electronics*, vol. 62, 1 2015.
- [131] Y. Huang, X. Yuan, J. Hu, and P. Zhou, "Modeling of vsc connected to weak grid for stability analysis of dc-link voltage control," *IEEE Journal of Emerging and Selected Topics in Power Electronics*, 2015.
- [132] A. Egea-Alvarez, S. Fekriasl, F. Hassan, and O. Gomis-Bellmunt, "Advanced vector control for voltage source converters connected to weak grids," *IEEE Transactions on Power Systems*, 2015.

- [133] C. Wan, M. Huang, C. K. Tse, and X. Ruan, "Effects of interaction of power converters coupled via power grid: A design-oriented study," *IEEE Transactions on Power Electronics*, vol. 30, 7 2015.
- [134] M. Liserre, R. Teodorescu, and F. Blaabjerg, "Stability of photovoltaic and wind turbine grid-connected inverters for a large set of grid impedance values," *IEEE Transactions on Power Electronics*, vol. 21, 2006.
- [135] M. Cespedes and J. Sun, "Impedance shaping of three-phase grid-parallel voltage-source converters," in *IEEE Applied Power Electronics Conference and Exposition - APEC 2012 - Orlando, FL, USA (2012.02.5-2012.02.9)*, 2012.
- [136] M. Xue, Y. Zhang, Y. Kang, Y. Yi, S. Li, and F. Liu, "Full feedforward of grid voltage for discrete state feedback controlled grid-connected inverter with lcl filter," *IEEE Transactions on Power Electronics*, vol. 27, 2012.
- [137] Y. Jia, J. Zhao, and X. Fu, "Direct grid current control of lcl-filtered grid-connected inverter mitigating grid voltage disturbance," *IEEE Transactions on Power Electronics*, vol. 29, 3 2014.
- [138] X. Chen, Y. Zhang, S. Wang, J. Chen, and C. Gong, "Impedance-phased dynamic control method for grid-connected inverters in a weak grid," *IEEE Transactions on Power Electronics*, vol. 32, no. 1, pp. 274–283, 2017.
- [139] L. Zhang, L. Harnefors, and H.-P. Nee, "Power-synchronization control of grid-connected voltage-source converters," *IEEE Transactions on Power Systems*, vol. 25, 2010.
- [140] L. Zhang, H.-P. Nee, and L. Harnefors, "Analysis of stability limitations of a vsc-hvdc link using power-synchronization control," *IEEE Transactions on Power Systems*, vol. 26, 08 2011.
- [141] Q.-C. Zhong, P.-L. Nguyen, Z. Ma, and W. Sheng, "Self-synchronized synchronverters: Inverters without a dedicated synchronization unit," *IEEE Transactions on Power Electronics*, vol. 29, 2 2014.
- [142] J. Meng, Y. Wang, C. Fu, and H. Wang, "Adaptive virtual inertia control of distributed generator for dynamic frequency support in microgrid," in *IEEE Energy*

- Conversion Congress and Exposition (ECCE) - Milwaukee, WI, USA (2016.9.18-2016.9.22)*, 2016.
- [143] Z. Wang, H. Yi, J. Wu, F. Zhuo, F. Wang, and Z. Zeng, "Dynamic performance analysis of paralleled virtual synchronous generators under grid-connected and islanded mode," in *IEEE Applied Power Electronics Conference and Exposition (APEC) - Tampa, FL, USA (2017.3.26-2017.3.30)*, 2017.
- [144] B. Wen, D. Boroyevich, R. Burgos, P. Mattavelli, and Z. Shen, "Small-signal stability analysis of three-phase ac systems in the presence of constant power loads based on measured d-q frame impedances," *IEEE Transactions on Power Electronics*, vol. 30, no. 10, 2015.
- [145] S. Sang, N. Gao, X. Cai, and R. Li, "A novel power-voltage control strategy for the grid-tied inverter to raise the rated power injection level in a weak grid," *IEEE Journal of Emerging and Selected Topics in Power Electronics*, 2017.
- [146] S. Mueeen, R. Takahashi, T. Murata, J. Tamura, M. Ali, Y. Matsumura, A. Kuwayama, and T. Matsumoto, "Low voltage ride through capability enhancement of wind turbine generator system during network disturbance," *IET Renewable Power Generation*, vol. 3, 2009.
- [147] A. Kasem, E. El-Saadany, H. El-Tamaly, and M. Wahab, "An improved fault ride-through strategy for doubly fed induction generator-based wind turbines," *IET Renewable Power Generation*, vol. 2, 2008.
- [148] S. Chondrogiannis and M. Barnes, "Specification of rotor side voltage source inverter of a doubly-fed induction generator for achieving ride-through capability," *IET Renewable Power Generation*, vol. 2, 2008.
- [149] J. Morren and S. de Haan, "Ridethrough of wind turbines with doubly-fed induction generator during a voltage dip," *IEEE Transactions on Energy Conversion*, vol. 20, 2005. [Online]. Available: <https://ieeexplore.ieee.org/document/1432858>
- [150] A. D. Hansen and M. Gabriele, "Fault ride-through capability of dfig wind turbines," *Renewable Energy*, vol. 32, 2007.

- [151] I. Erlich, J. Kretschmann, J. Fortmann, S. Mueller-Engelhardt, and H. Wrede, "Modeling of wind turbines based on doubly-fed induction generators for power system stability studies," *IEEE Transactions on Power Systems*, vol. 22, 2007.
- [152] J. Niiranen, "Voltage dip ride through of a doubly-fed generator equipped with an active crowbar," 03 2004.
- [153] M. Kayikci and J. Milanovic, "Assessing transient response of dfig-based wind plants the influence of model simplifications and parameters," *IEEE Transactions on Power Systems*, vol. 23, 2008.
- [154] L. Peng, B. Francois, and Y. Li, "Improved crowbar control strategy of dfig based wind turbines for grid fault ride-through," in *IEEE 2009 Twenty-Fourth Annual IEEE Applied Power Electronics Conference and Exposition (APEC) - Washington, DC, USA (2009.02.15-2009.02.19)*, 2009.
- [155] P. Flannery and G. Venkataramanan, "A fault tolerant doubly fed induction generator wind turbine using a parallel grid side rectifier and series grid side converter," *IEEE Transactions on Power Electronics*, vol. 23, 2008.
- [156] G. Venkataramanan and P. Flannery, "Unbalanced voltage sag ride-through of a doubly fed induction generator wind turbine with series grid-side converter," *IEEE Transactions on Industry Applications*, vol. 45, 2009.
- [157] N. Joshi and N. Mohan, "A novel scheme to connect wind turbines to the power grid," *IEEE Transactions on Energy Conversion*, vol. 24, 2009.
- [158] D. Anca, N. Cutululis, P. Sorensen, F. Iov, and T. Larsen, "Simulation of a flexible wind turbine response to a grid fault," *European Wind Energy Conference and Exhibition 2007, EWEC 2007*, vol. 2, 01 2007.
- [159] Y. Xingjia, L. Lizhe, and X. Zuoxia, "Dynamic characteristic of the drive train of dfig wind turbines during grid faults," in *Second International Conference on Intelligent Computation Technology and Automation - Changsha, Hunan, China (2009.10.10-2009.10.11)*, 2009.



- [160] D. Santos-Martin, J. Rodriguez-Amenedo, and S. Arnaltes, "Providing ride-through capability to a doubly fed induction generator under unbalanced voltage dips," *IEEE Transactions on Power Electronics*, vol. 24, 2009.
- [161] M. Rahimi and M. Parniani, "Efficient control scheme of wind turbines with doubly fed induction generators for low-voltage ride-through capability enhancement," *Renewable Power Generation, IET*, vol. 4, pp. 242 – 252, 06 2010.
- [162] M. Molinas, J. A. Suul, and T. Undeland, "Low voltage ride through of wind farms with cage generators: Statcom versus svc," *IEEE Transactions on Power Electronics*, vol. 23, 2008.
- [163] S. Mueen, R. Takahashi, T. Murata, J. Tamura, and M. H. Ali, "Application of statcom/bess for wind power smoothening and hydrogen generation," *Electric Power Systems Research*, vol. 79, 2009.
- [164] F. Blaabjerg, R. Teodorescu, M. Liserre, and A. Timbus, "Overview of control and grid synchronization for distributed power generation systems," *IEEE Transactions on Industrial Electronics*, vol. 53, 2006.
- [165] M. Hossain, H. Pota, V. Ugrinovskii, and R. Ramos, "Simultaneous statcom and pitch angle control for improved lvr capability of fixed-speed wind turbines," *IEEE Transactions on Sustainable Energy*, vol. 1, 2010.
- [166] R. Sakamoto, T. Senjyu, T. Kaneko, N. Urasaki, T. Takagi, and S. Sugimoto, "Output power leveling of wind turbine generator by pitch angle control using  $h_\infty$  control," *Electrical Engineering in Japan*, vol. 162, 2008.
- [167] T. Senjyu, Y. Kikunaga, A. Yona, H. Sekine, A. Y. Saber, and T. Funabashi, "Coordinate control of wind turbine and battery in wind power generator system," in *IEEE Power and Energy Society General Meeting - Conversion and Delivery of Electrical Energy in the 21st Century - Pittsburgh, PA, USA (2008.07.20-2008.07.24)*, 2008.
- [168] W. Qiao and R. G. Harley, "Power quality and dynamic performance improvement of wind farms using a statcom," in *IEEE Power Electronics Specialists Conference - Orlando, FL, USA (2007.06.17-2007.06.21)*, 2007.

- [169] M. J. Hossain, H. R. Pota, V. Ugrinovskii, and R. A. Ramos, "Excitation control for large disturbances in power systems with dynamic loads," in *IEEE Power & Energy Society General Meeting (PES), Calgary, Canada (2009.07.26-2009.07.30)*, 2009.
- [170] O. Goksu, R. Teodorescu, C. L. Bak, F. Iov, and P. C. Kjaer, "Instability of wind turbine converters during current injection to low voltage grid faults and pll frequency based stability solution," *IEEE Transactions on Power Systems*, vol. 29, 7 2014.
- [171] I. Erlich, F. Shewarega, S. Engelhardt, J. Kretschmann, J. Fortmann, and F. Koch, "Effect of wind turbine output current during faults on grid voltage and the transient stability of wind parks," in *IEEE Power & Energy Society General Meeting, Calgary, Canada (2009.07.26-2009.07.30)*, 2009.
- [172] H. Markiewicz and A. Klajn, *Voltage Disturbances Standard EN 50160 - Voltage Characteristics in Public Distribution Systems*, EN EN50 160, 2008.
- [173] C. H. Benz, W. T. Franke, and F. W. Fuchs, "Low voltage ride through capability of a 5 kw grid-tied solar inverter," in *Proceedings of 14th International Power Electronics and Motion Control Conference EPE-PEMC 2010, Ohrid, Macedonia (2010.09.6-2010.09.8)*, 2010.
- [174] Y. Yang, H. Wang, and F. Blaabjerg, "Reactive power injection strategies for single-phase photovoltaic systems considering grid requirements," *IEEE Transactions on Industry Applications*, vol. 50, 11 2014.
- [175] Y. Yang, F. Blaabjerg, and Z. Zou, "Benchmarking of grid fault modes in single-phase grid-connected photovoltaic systems," *IEEE Transactions on Industry Applications*, vol. 49, 09 2013.
- [176] G. Saccomando and J. Svensson, "Transient operation of grid-connected voltage source converter under unbalanced voltage conditions," in *Conference Record of the 2001 IEEE Industry Applications Conference. 36<sup>th</sup> IAS Annual Meeting (Cat. No.01CH37248), Chicago, IL, USA (30 Sept.-4 Oct. 2001)*, vol. 4, 2001.

- [177] F. Magueed and J. Svensson, "Control of vsc connected to the grid through lcl - filter to achieve balanced currents," in *IEEE Fourtieth IAS Annual Meeting. Conference Record of the 2005 Industry Applications Conference, Hong Kong, China (2-6 Oct. 2005)*, vol. 1, 2005.
- [178] S. Yongsug, V. Tijeras, and T. Lipo, "[ieee 2002 ieee industry applications society annual meeting - pittsburgh, pa, usa (13-18 oct. 2002)] conference record of the 2002 ieee industry applications conference. 37th ias annual meeting (cat. no.02ch37344) - a nonlinear control of the instantaneous power in dq synchronous frame for pwm ac/dc converter under generalized unbalanced operating conditions," vol. 2, 2002.
- [179] L. Chia-Tse, H. Che-Wei, and C. Po-Tai, "A low-voltage ride-through technique for grid-connected converters of distributed energy resources," *IEEE Transactions on Industry Applications*, vol. 47, 2011.
- [180] G. Ding, F. Gao, H. Tian, C. Ma, M. Chen, G. He, and Y. Liu, "Adaptive dc-link voltage control of two-stage photovoltaic inverter during low voltage ride-through operation," *IEEE Transactions on Power Electronics*, 2015.
- [181] H. Markiewicz and A. Klajn, *Grid Code High and Extra High Voltage*, E.ON Netz GmbH, Bayreuth, Germany, 2006. [Online]. Available: <http://www.eon-netz.com>
- [182] "The grid code," National Grid Electricity Transmission plc, Warwick, U.K., Tech. Rep. 4, 2010. [Online]. Available: <http://www.nationalgrid.com/uk>
- [183] "Regulation of 3.2.5 wind turbines connected to grids with voltages above 100 kv," Energinet, Denmark, Tech. Rep., 2010.
- [184] "Distribution system operator, esb networks, distribution code v2.0," Tech. Rep., 2007. [Online]. Available: <http://www.esb.ie/esbnetworks/en/downloads/Distribution-Code.pdf>
- [185] "Technical requirements for connecting photovoltaic power station to power system," China, Tech. Rep. GB/T 19964-2012, 2012.
- [186] H. Tian, F. Gao, and C. Ma, "Novel low voltage ride through strategy of single-stage grid-tied photovoltaic inverter with supercapacitor coupled," in *Proceedings of The*

- 7<sup>th</sup> International Power Electronics and Motion Control Conference (IPEMC 2012)*  
- Harbin, China (2012.06.2-2012.06.5), 2012.
- [187] H. Tian, F. Gao, G. He, and G. Li, "Low voltage ride through of two-stage photovoltaic inverter with enhanced operational performance," in *Twenty-Seventh Annual IEEE Applied Power Electronics Conference and Exposition (APEC) - APEC 2012* - Orlando, FL, USA (2012.02.5-2012.02.9), 2012.
- [188] E. Styvaktakis, M. Bollen, and I. Gu, "Automatic classification of power system events using rms voltage measurements," in *IEEE Power Engineering Society Summer Meeting, Chicago, IL, USA (21-25 July 2002)*, vol. 2, 2002.
- [189] R. Naidoo and P. Pillay, "A new method of voltage sag and swell detection," *IEEE Transactions on Power Delivery*, vol. 22, 04 2007.
- [190] F. Liccardo, P. Marino, and G. Raimondo, "Robust and fast three-phase pll tracking system," *IEEE Transactions on Industrial Electronics*, vol. 58, 2011.
- [191] I. Carugati, S. Maestri, P. G. Donato, D. Carrica, and M. Benedetti, "Variable sampling period filter pll for distorted three-phase systems," *IEEE Transactions on Power Electronics*, vol. 27, 01 2012.
- [192] Y. F. Wang and Y. Wei Li, "Analysis and digital implementation of cascaded delayed-signal-cancellation pll," *IEEE Transactions on Power Electronics*, vol. 26, 04 2011.
- [193] "Enhancing the three-phase synchronous reference frame pll to remove unbalance and harmonic errors," in *35th Annual Conference of IEEE Industrial Electronics (IECON) - Porto, Portugal (2009.11.3-2009.11.5)*.
- [194] B. Sun, N.-Y. Dai, U.-F. Chio, M.-C. Wong, C.-K. Wong, S.-W. Sin, U. Seng-Pan, and R. P. Martins, "Fpga-based decoupled double synchronous reference frame pll for active power filters," in *6<sup>th</sup> IEEE Conference on Industrial Electronics and Applications (ICIEA) - Beijing, China (2011.06.21-2011.06.23)*, 2011.
- [195] P. Rodriguez, J. Pou, J. Bergas, J. Candela, R. Burgos, and D. Boroyevich, "Decoupled double synchronous reference frame pll for power converters control," *IEEE Transactions on Power Electronics*, vol. 22, 2007.

- [196] D. Yazdani, M. Mojiri, A. Bakhshai, and G. Joos, "A fast and accurate synchronization technique for extraction of symmetrical components," *IEEE Transactions on Power Electronics*, vol. 24, 2009.
- [197] S. A. Oliveira da Silva, R. Novochadlo, and R. A. Modesto, "Single-phase pll structure using modified p-q theory for utility connected systems," in *IEEE Power Electronics Specialists Conference - PESC 2008 - Rhodes, Greece (2008.06.15-2008.06.19)*, 2008.
- [198] M. Karimi-Ghartemani, "A unifying approach to single-phase synchronous reference frame plls," *IEEE Transactions on Power Electronics*, vol. 28, 10 2013.
- [199] C. Ma, F. Gao, G. He, and G. Li, "A voltage detection method for the voltage ride-through operation of renewable energy generation systems under grid voltage distortion conditions," *IEEE Transactions on Sustainable Energy*, vol. 6, 7 2015.
- [200] E. Lopez, J. and Gubia, E. Olea, J. Ruiz, and L. Marroyo, "Ride through of wind turbines with doubly fed induction generator under symmetrical voltage dips," *IEEE Transactions on Industrial Electronics*, vol. 56, 2009.
- [201] L. Meegahapola, T. Littler, and D. Flynn, "Decoupled-dfig fault ride-through strategy for enhanced stability performance during grid faults," *IEEE Transactions on Sustainable Energy*, vol. 1, 2010.
- [202] J. Liang, W. Qiao, and R. Harley, "Feed-forward transient current control for low-voltage ride-through enhancement of dfig wind turbines," *IEEE Transactions on Energy Conversion*, vol. 25, 2010.
- [203] T. D. Vrionis, X. I. Koutiva, and N. A. Vovos, "A genetic algorithm-based low voltage ride-through control strategy for grid connected doubly fed induction wind generators," *IEEE Transactions on Power Systems*, vol. 29, 5 2014.
- [204] P.-H. Huang, M. S. El Moursi, W. Xiao, and J. L. Kirtley Jr, "Novel fault ride-through configuration and transient management scheme for doubly fed induction generator," *IEEE Transactions on Energy Conversion*, vol. 28, 03 2013.

- [205] Y. Jin, J. Fletcher, and J. O'Reilly, "A series-dynamic-resistor-based converter protection scheme for doubly-fed induction generator during various fault conditions," *IEEE Transactions on Energy Conversion*, vol. 25, 2010.
- [206] F. Nielsen, J.G. and Blaabjerg, "A detailed comparison of system topologies for dynamic voltage restorers," *IEEE Transactions on Industry Applications*, vol. 41, 2005.
- [207] C. Abbey and G. Joos, "Supercapacitor energy storage for wind energy applications," *IEEE Transactions on Industry Applications*, vol. 43, 2007.
- [208] P. Kanjiya, B. B. Ambati, and V. Khadkikar, "A novel fault-tolerant dfig-based wind energy conversion system for seamless operation during grid faults," *IEEE Transactions on Power Systems*, vol. 29, 5 2014.
- [209] R. Cardenas, R. Pena, S. Alepuz, and G. Asher, "Overview of control systems for the operation of dfigs in wind energy applications," *IEEE Transactions on Industrial Electronics*, vol. 60, 07 2013.
- [210] M. Mohseni and S. Islam, "Transient control of dfig-based wind power plants in compliance with the australian grid code," *IEEE Transactions on Power Electronics*, vol. 27, 2012.
- [211] D. Xie, Z. Xu, L. Yang, J. Ostergaard, Y. Xue, and K. P. Wong, "A comprehensive lvrt control strategy for dfig wind turbines with enhanced reactive power support," *IEEE Transactions on Power Systems*, vol. 28, 08 2013.
- [212] Y.-W. Shen, D.-P. Ke, W. Qiao, Y.-Z. Sun, D. S. Kirschen, and C. Wei, "Transient reconfiguration and coordinated control for power converters to enhance the lvrt of a dfig wind turbine with an energy storage device," *IEEE Transactions on Energy Conversion*, 2015.
- [213] P. Pratim Das and S. Chattopadhyay, "A voltage independent islanding detection method and low voltage ride through of a two stage pv inverter," *IEEE Transactions on Industry Applications*, 2018.
- [214] Z. Xie, Q. Shi, H. Song, X. Zhang, and S. Yang, "High voltage ride through control strategy of doubly fed induction wind generators based on active resistance," in

- Proceedings of The 7th International Power Electronics and Motion Control Conference*, vol. 3, 2012, pp. 2193–2196.
- [215] J. da Costa, H. Pinheiro, T. Degner, and G. Arnold, “Robust controller for dfigs of grid-connected wind turbines,” *IEEE Transactions on Industrial Electronics*, vol. 58, 2011.
- [216] S. Hu, X. Lin, Y. Kang, and X. Zou, “An improved low-voltage ride-through control strategy of doubly fed induction generator during grid faults,” *IEEE Transactions on Power Electronics*, vol. 26, 2011.
- [217] S. Xiao, G. Yang, H. Zhou, and H. Geng, “A lvrt control strategy based on flux linkage tracking for dfig-based wecs,” *IEEE Transactions on Industrial Electronics*, 2012.
- [218] Y. Ma, H. Wen, X. Zhou, J. Li, and H. Yang, “Bifurcation analysis of voltage stability and study on power loss for wind power system,” in *IEEE 2009 World Non-Grid-Connected Wind Power and Energy Conference (WNWEC 2009) - Nanjing, China (2009.09.24-2009.09.26)*, 2009.
- [219] R. M. M. Pereira, C. M. M. Ferreira, and F. P. M. Barbosa, “Comparative study of statcom and svc performance on dynamic voltage collapse of an electric power system with wind generation,” *IEEE Latin America Transactions*, vol. 12, 03 2014.
- [220] M. Asmine, J. Brochu, J. Fortmann, R. Gagnon, Y. Kazachkov, C. Langlois, C. Larose, E. Muljadi, J. MacDowell, P. Pourbeik, S. Seman, and K. Wiens, “Model validation for wind turbine generator models,” *IEEE Transactions on Power Systems*, vol. 26, 2011.
- [221] O. Goksu, M. Altin, J. Fortmann, and P. Sorensen, “Field validation of iec 61400-27-1 wind generation type 3 model with plant power factor controller,” *IEEE Transactions on Energy Conversion*, 2016.
- [222] J. Ouyang, T. Tang, J. Yao, and M. Li, “Active voltage control for dfig-based wind farm integrated power system by coordinating active and reactive powers under wind speed variations,” *IEEE Transactions on Energy Conversion*, 2019.

- [223] V. Akhmatov and P. B. Eriksen, "A large wind power system in almost island operationa danish case study," *IEEE Transactions on Power Systems*, vol. 22, 08 2007.
- [224] R. Ou, X. Y. Xiao, Z. C. Zou, Y. Zhang, and Y. H. Wang, "Cooperative control of sfcl and reactive power for improving the transient voltage stability of grid-connected wind farm with dfigs," *IEEE Transactions on Appiled Superconductivity*, 2016.
- [225] J. Liu, Y. Xu, Z. Dong, and K. P. Wong, "Retirement-driven dynamic var planning for voltage stability enhancement of power systems with high-level wind power," *IEEE Transactions on Power Systems*, 2017.
- [226] N. Ullah, T. Thiringer, and D. Karlsson, "Voltage and transient stability support by wind farms complying with the e.on netz grid code," *IEEE Transactions on Power Systems*, vol. 22, 2007.
- [227] H. T. Le, S. Santoso, and T. Q. Nguyen, "Augmenting wind power penetration and grid voltage stability limits using ess: Application design, sizing, and a case study," *IEEE Transactions on Power Systems*, vol. 27, 2012.
- [228] C. Han, A. Huang, M. Baran, S. Bhattacharya, W. Litzenberger, L. Anderson, A. Johnson, and A. A. Edris, "Statcom impact study on the integration of a large wind farm into a weak loop power system," *IEEE Transactions on Energy Conversion*, vol. 23, 2008.
- [229] C. Rahmann, H. Haubrich, A. Moser, R. Palma-Behnke, L. Vargas, and M. Salles, "Justified fault-ride-through requirements for wind turbines in power systems," *IEEE Transactions on Power Systems*, vol. 26, 2011.
- [230] Z. H. Rather, Z. Chen, P. Thogersen, and P. Lund, "Dynamic reactive power compensation of large-scale wind integrated power system," *IEEE Transactions on Power Systems*, vol. 30, 9 2015.
- [231] H. Liu and J. Sun, "Voltage stability and control of offshore wind farms with ac collection and hvdc transmission," *IEEE Journal of Emerging and Selected Topics in Power Electronics*, vol. 2, 12 2014.



- [232] N. R. Ullah and T. Thiringer, "Variable speed wind turbines for power system stability enhancement," *IEEE Transactions on Energy Conversion*, vol. 22, 03 2007.
- [233] Y. Li, L. Fan, and Z. Miao, "Stability control for wind in weak grids," *IEEE Transactions on Sustainable Energy*, 2018.
- [234] S. De Rijcke, H. Ergun, D. Van Hertem, and J. Driesen, "Grid impact of voltage control and reactive power support by wind turbines equipped with direct-drive synchronous machines," *IEEE Transactions on Sustainable Energy*, vol. 3, 10 2012.
- [235] K. Zhang, G. Geng, and Q. Jiang, "Online tracking of reactive power reserve for wind farms," *IEEE Transactions on Sustainable Energy*, 2019.
- [236] V. S. S. Kumar, K. K. Reddy, and D. Thukaram, "Coordination of reactive power in grid-connected wind farms for voltage stability enhancement," *IEEE Transactions on Power Systems*, vol. 29, 9 2014.
- [237] A. A. Tamimi, A. Pahwa, and S. Starrett, "Effective wind farm sizing method for weak power systems using critical modes of voltage instability," *IEEE Transactions on Power Systems*, vol. 27, 2012.
- [238] N. Jelani and M. Molinas, "Asymmetrical fault ride through as ancillary service by constant power loads in grid-connected wind farm," *IEEE Transactions on Power Electronics*, vol. 30, 3 2015.
- [239] S. Yang, W. Wang, C. Liu, and Y. Huang, "Optimal reactive power dispatch of wind power plant cluster considering static voltage stability for low-carbon power system," *Journal of Modern Power Systems and Clean Energy*, vol. 3, 3 2015.
- [240] T. Cui, Y. Shen, B. Zhang, J. Xu, S. Xiong, K. Zhang, and L. Liang, "Pmus-based voltage control of isolated power systems with high penetration of wind power," *IEEE Transactions on Sustainable Energy*, 2017.
- [241] R. R. Londero, C. d. M. Affonso, and J. P. A. Vieira, "Long-term voltage stability analysis of variable speed wind generators," *IEEE Transactions on Power Systems*, vol. 30, 1 2015.

- [242] E. Muljadi, C. Butterfield, and A. Parsons, B.; Ellis, "Effect of variable speed wind turbine generator on stability of a weak grid," *IEEE Transactions on Energy Conversion*, vol. 22, 2007.
- [243] K. Yang, M. H. Bollen, and M. Wahlberg, "A comparison study of harmonic emission measurements in four windparks," in *IEEE Energy Society General Meeting - Detroit, MI, USA (2011.07.24-2011.07.29)*, 2011. [Online]. Available: <https://ieeexplore.ieee.org/document/6038926>
- [244] K. Yang, M. Wahlberg, and M. H. Bollen, "Comparison of harmonic emissions at two nodes in a windpark," in *IEEE 15th International Conference on Harmonics and Quality of Power (ICHQP) - Hong Kong, China (2012.06.17-2012.06.20)*, 2012. [Online]. Available: <https://ieeexplore.ieee.org/document/6381163>
- [245] L. Sainz, J. J. Mesas, R. Teodorescu, and P. Rodriguez, "Deterministic and stochastic study of wind farm harmonic currents," *IEEE Transactions on Energy Conversion*, vol. 25, 12 2010. [Online]. Available: <https://ieeexplore.ieee.org/document/5477160>
- [246] P. Ribeiro, "An overview of probabilistic aspects of harmonics: state of the art and new developments," in *IEEE Power Engineering Society General Meeting, 2005 - San Francisco, CA, USA (June 12-16, 2005)*, 2005. [Online]. Available: <https://ieeexplore.ieee.org/document/1489555>
- [247] "A new approach for harmonic summation using the methodology of iec 61400-21," in *IEEE-2010, 14th International Conference on Harmonics and Quality of Power (ICHQP) - Bergamo, Italy (2010.09.26-2010.09.29)*.
- [248] X. R. Morales and J. Maun, "Assessment of wind power quality: Implementation of iec61400-21 procedures," *Renewable Energy and Power Quality Journal*, vol. 1050, 12 2005.
- [249] S. Y. Liu, C. M. Pimenta, H. A. Pereira, V. F. Mendes, G. A. Mendonca, and S. R. Silva, *Aggregated Dfig Wind Farm Harmonic Propagation Analysis*, 2012.

- [250] F. Ghassemi and K. Kah-Leong, "Equivalent network for wind farm harmonic assessments," *IEEE Transactions on Power Delivery*, vol. 25, 2010. [Online]. Available: <https://ieeexplore.ieee.org/document/5491370>
- [251] K. M. Hasan, K. Rauma, P. Rodriguez, J. Ignacio Candela, R. S. Munoz-Aguilar, and A. Luna, "An overview of harmonic analysis and resonances of large wind power plant," in *[IEEE, IECON 2011 - 37th Annual Conference of IEEE Industrial Electronics - Melbourne, Vic, Australia (2011.11.7-2011.11.10)]*, 2011. [Online]. Available: <https://ieeexplore.ieee.org/document/5491370>
- [252] M. H. J. Bollen and K. Yang, "Harmonic aspects of wind power integration," *Journal of Modern Power Systems and Clean Energy*, vol. 1, 06 2013. [Online]. Available: <https://ieeexplore.ieee.org/stamp/stamp.jsp?arnumber=8939544>
- [253] S. Santoso, H. Wayne Beaty, R. C. Dugan, and M. F. McGranaghan, *Electrical Power Systems Quality*, 2nd ed. McGraw-Hill Professional, 2002.
- [254] J. Rueda, D. Colome, and I. Erlich, "Assessment and enhancement of small signal stability considering uncertainties," *IEEE Transactions on Power Systems*, vol. 24, 02 2009.
- [255] N. Dahal, S. and Mithulananthan and T. Saha, "Assessment and enhancement of small signal stability of a renewable-energy-based electricity distribution system," *IEEE Transactions on Sustainable Energy*, vol. 3, 2012.
- [256] G. Tsourakis, B. Nomikos, and C. Vournas, "Effect of wind parks with doubly fed asynchronous generators on small-signal stability," *Electric Power Systems Research*, vol. 79, 2009.
- [257] D. Chandra, M. S. Kumari, M. Sydulu, F. Grimaccia, M. Mussetta, S. Leva, and M. Duong, "[ieee 2014 annual ieee india conference (indicon) - pune, india (2014.12.11-2014.12.13)] 2014 annual ieee india conference (indicon) - small signal stability of power system with scig, dfig wind turbines," 2014.
- [258] N. Martins, "Efficient eigenvalue and frequency response methods applied to power system small-signal stability studies," *IEEE Transactions on Power Systems*, vol. 1, 1986.

- [259] Z. Xu, Z. Dong, and P. Zhang, "Probabilistic small signal analysis using monte carlo simulation," in *IEEE Power Engineering Society General Meeting, San Francisco, CA, USA (June 12-16, 2005)*, 2005.
- [260] D. Gautam, V. Vittal, and T. Harbour, "Impact of increased penetration of dfig-based wind turbine generators on transient and small signal stability of power systems," *IEEE Transactions on Power Systems*, vol. 24, 2009.
- [261] W. W. K. L. G. H. B. Jin Xu, ; Wu, "Probabilistic small signal analysis considering wind power correlation," in *IEEE Power and Energy Society General Meeting (PESGM), Boston, MA, USA (2016.7.17-2016.7.21)*, 2016.
- [262] I. J. Perez-Arriaga, G. C. Verghese, F. L. Pagola, J. L. Sancha, and F. C. Schweppe, "Developments in selective modal analysis of small-signal stability in electric power systems," *Automatica*, vol. 26, 1990.
- [263] H. Jia, X. Yu, and C. Yu, Yixin amd Wang, "Power system small signal stability region with time delay," *International Journal of Electrical Power & Energy Systems*, vol. 30, 2008.
- [264] X. Wu, F.and Zhang and P. Ju, "Small signal stability analysis and control of the wind turbine with the direct-drive permanent magnet generator integrated to the grid," *Electric Power Systems Research*, vol. 79, 2009.
- [265] M. Rahman, A. Osheiba, T. Radwan, and E. Abdin, "Modelling and controller design of an isolated diesel engine permanent magnet synchronous generator," *IEEE Transactions on Energy Conversion*, vol. 11, 6 1996.
- [266] S. Chatterjee, A. Naithani, and V. Mukherjee, "Small-signal stability analysis of dfig based wind power system using teaching learning based optimization," *International Journal of Electrical Power & Energy Systems*, vol. 78, 06 2016.
- [267] H. A. Mohammadpour and E. Santi, "Modeling and control of gate-controlled series capacitor interfaced with a dfig-based wind farm," *IEEE Transactions on Industrial Electronics*, vol. 62, 2 2015.
- [268] R. Zarate-Minano, F. Milano, and A. Conejo, "An opf methodology to ensure small-signal stability," *IEEE Transactions on Power Systems*, vol. 26, 2011.

- [269] Y. Mishra, S. Mishra, F. Li, Z. Y. Dong, and R. Bansal, "Small-signal stability analysis of a dfig-based wind power system under different modes of operation," *IEEE Transactions on Energy Conversion*, vol. 24, 2009.
- [270] F. Mei and B. Pal, "Modelling and small-signal analysis of a grid connected doubly-fed induction generator," in *IEEE Power Engineering Society General Meeting, San Francisco, CA, USA (June 12-16, 2005)*, 2005.
- [271] L. Yazhou, A. Mullane, and R. Lightbody, G.and Yacamini, "Modeling of the wind turbine with a doubly fed induction generator for grid integration studies," *IEEE Transactions on Energy Conversion*, vol. 21, 2006.
- [272] Z. Miao and L. Fan, "The art of modeling and simulation of induction generator in wind generation applications using high-order model," *Simulation Modelling Practice and Theory*, vol. 16, 2008.
- [273] B. Mehta, P. Bhatt, and V. Pandya, "Small signal stability analysis of power systems with dfig based wind power penetration," *International Journal of Electrical Power & Energy Systems*, vol. 58, 06 2014.
- [274] F. Pal, B.C.and Mei, "Modelling adequacy of the doubly fed induction generator for small-signal stability studies in power systems," *IET Renewable Power Generation*, vol. 2, 2008.
- [275] L. Fernandez and F. Garcia, C.A.and Jurado, "Comparative study on the performance of control systems for doubly fed induction generator (dfig) wind turbines operating with power regulation," *Energy*, vol. 33, 2008.
- [276] M. Kayikci and J. Milanovic, "Dynamic contribution of dfig-based wind plants to system frequency disturbances," *IEEE Transactions on Power Systems*, vol. 24, 05 2009.
- [277] J. Hu, H. Nian, H. Xu, and Y. He, "Dynamic modeling and improved control of dfig under distorted grid voltage conditions," *IEEE Transactions on Energy Conversion*, vol. 26, 03 2011.

- [278] I. Margaris, N. Papathanassiou, S.A. and Hatziaargyriou, and P. Hansen, A.D.; Sorensen, "Frequency control in autonomous power systems with high wind power penetration," *IEEE Transactions on Sustainable Energy*, vol. 3, 2012.
- [279] J. F. Conroy and R. Watson, "Frequency response capability of full converter wind turbine generators in comparison to conventional generation," *IEEE Transactions on Power Systems*, vol. 23, 05 2008.
- [280] K. Hee-Sang, Y. Gi-Gab, K. Nam-Ho, and H. Won-Pyo, "Modeling and control of dfig-based variable-speed wind-turbine," *Electric Power Systems Research*, vol. 78, 2008.
- [281] "Definition and classification of power system stability ieee/cigre joint task force on stability terms and definitions," *IEEE Transactions on Power Systems*, vol. 19, 2004. [Online]. Available: <https://ieeexplore.ieee.org/abstract/document/1318675>
- [282] N. G. Hingorani and L. Gyugyi, *Understanding FACTS: Concepts and Technology of Flexible AC Transmission Systems*. Wiley-IEEE Press, 1999.
- [283] S. Lian, S. Minami, S.; Morii, and S. Kawamoto, "Analysis method of voltage stability for bulk power system by p-v and q-v curves considering dynamic load," in *IEEE 2009 IEEE/PES Power Systems Conference and Exposition (PSCE) - Seattle, WA, USA (2009.03.15-2009.03.18)*, 2009.
- [284] H. Chen, J. Chen, D. Shi, and X. Duan, "Power flow study and voltage stability analysis for distribution systems with distributed generation," in *IEEE 2006 IEEE Power Engineering Society General Meeting - Montreal, Que., Canada (2006.06.18-2006.06.22)*, 2006.
- [285] B. Gao, G. Morison, and P. Kundur, "Voltage stability evaluation using modal analysis," *IEEE Transactions on Power Systems*, vol. 7, 1992.
- [286] "Npsc 2004, iit madras, voltage stability improvement using modal analysis based compensation," 2008.
- [287] C. Sharma and M. G. Ganness, "[ ] 2008 ieee/pes transmission and distribution conference and exposition - determination of the applicability of using modal analysis

- for the prediction of voltage stability,” in *IEEE Exposition - Chicago, IL, USA (2008.04.21-2008.04.24)*, 2008.
- [288] “Practical application of modal analysis for increasing voltage stability margins,” in *IEEE Joint International Power Conference Athens Power Tech, Athens, Greece (September 5-8, 1993)*.
- [289] C. Canizares, “On bifurcations, voltage collapse and load modeling,” *IEEE Transactions on Power Systems*, vol. 10, Feb. 1995.
- [290] “Effect of wind generation uncertainty on voltage stability - a singular value analysis,” in *IEEE 2018 IEEE Electrical Power and Energy Conference (EPEC) - Toronto, ON (2018.10.10-2018.10.11)*.
- [291] I. G. Adebayo, A. A. Jimoh, and A. A. Yusuff, “A comparison of voltage collapse point prediction capabilities of voltage stability index and inherent structural characteristics,” in *IEEE AFRICON 2015 - Addis Ababa, Ethiopia (2015.9.14-2015.9.17)*, 2015.
- [292] A. Chakrabarti and S. Halder, *Power System Analysis Operation and Control*, 1st ed., 2010.
- [293] V. Ajjarapu, *Computational Techniques for Voltage Stability Assessment and Control (Power Electronics and Power Systems)*, 1st ed., 2006.
- [294] P. W. Sauer and M. A. Pai, *Power System Dynamics and Stability*, 1st ed. Prentice Hall, 1998.
- [295] M. Pai, *Energy Function Analysis for Power System Stability*, 1st ed., ser. The Kluwer International Series in Engineering and Computer Science. Springer US, 1989.
- [296] R. Y. Rubinstein, *Simulation and the Monte Carlo Method*, ser. Wiley series in probability and mathematical statistics. Wiley, 1981.
- [297] J. M. Morales and J. Perez-Ruiz, “Point estimate schemes to solve the probabilistic power flow,” *IEEE Transactions on Power Systems*, vol. 22, 11 2007.

- [298] K. Li, S. Li, D. Li, and Q. Niu, *Two-Point Estimate Method for Probabilistic Optimal Power Flow Computation Including Wind Farms with Correlated Parameters*, 2013, vol. 10.1007/978-3-642-37105-9.
- [299] G. Verbic and C. Canizares, “Probabilistic optimal power flow in electricity markets based on a two-point estimate method,” *IEEE Transactions on Power Systems*, vol. 21, 2006.
- [300] H. Hong, “An efficient point estimate method for probabilistic analysis,” *Reliability Engineering & System Safety*, vol. 59, 1998.
- [301] L. Zhi-Zhao, W. Li, and M. Yang, “Two general extension algorithms of latin hypercube sampling,” *Mathematical Problems in Engineering*, vol. 2015, 2015.
- [302] Y. Yuan, J. Zhou, P. Ju, and J. Feuchtwang, “Probabilistic load flow computation of a power system containing wind farms using the method of combined cumulants and gram charlier expansion,” *IET Renewable Power Generation*, vol. 5, 2011.
- [303] J. Munkhammar, L. Mattsson, J. Rydn, and F. Rapallo, “Polynomial probability distribution estimation using the method of moments,” *PLoS ONE*, vol. 12, 4 2017.
- [304] A. Schellenberg, W. Rosehart, and J. Aguado, “Cumulant-based probabilistic optimal power flow (p-opf) with gaussian and gamma distributions,” *IEEE Transactions on Power Systems*, vol. 20, 05 2005.
- [305] L. Cohen, “Generalization of the gram-charlier/edgeworth series and application to time-frequency analysis,” *Multidimensional Systems and Signal Processing*, vol. 9, 10 1998.
- [306] A. C. Miller and T. R. Rice, “Discrete approximations of probability distributions,” 1983.
- [307] E. Rosenblueth, “Point estimates for probability moments,” *Proceedings of the National Academy of Sciences*, vol. 72, 10 1975.
- [308] B. G. M. Husslage, G. Rennen, E. R. VanDam, and D. Hertog, “Space-filling latin hypercube designs for computer experiments,” *Optimization and Engineering*, vol. 12, 12 2011.



- [309] J. Helton, F. Davis, and J. Johnson, "A comparison of uncertainty and sensitivity analysis results obtained with random and latin hypercube sampling," *Reliability Engineering & System Safety*, vol. 89, 2005.
- [310] G. G. Wang and S. Shan, "Review of metamodeling techniques in support of engineering design optimization-parts a and b," in *ASME 2006 International Design Engineering Technical Conferences and Computers and Information in Engineering Conference - Philadelphia, Pennsylvania, USA (September 10/13, 2006)*, vol. 2006, 2006.
- [311] A. Olsson, G. Sandberg, and O. Dahlblom, "On latin hypercube sampling for structural reliability analysis," *Structural Safety*, vol. 25, 2003.
- [312] H. Yu, C. Chung, K. Wong, and J. Zhang, "A probabilistic load flow calculation method with latin hypercube sampling," *Automation of Electric Power Systems*, vol. 33, 2009.
- [313] C. Ong, "Refinement strategies for stratified sampling methods," *Reliability Engineering & System Safety*, vol. 91, 2006.
- [314] C. Sallaberry, J. Helton, and S. Hora, "Extension of latin hypercube samples with correlated variables," *Reliability Engineering & System Safety*, vol. 93, 2008.
- [315] P. Z. G. Qian, "Nested latin hypercube designs," *Biometrika*, vol. 96, 12 2009.
- [316] X. He and P. Z. G. Qian, "Nested orthogonal array-based latin hypercube designs," *Biometrika*, vol. 98, 09 2011.
- [317] D. Williamson, "Exploratory ensemble designs for environmental models using k-extended latin hypercubes," *Environmetrics*, vol. 26, 06 2015.
- [318] K. Dongbum, K. Kyungnam, and H. Jongchul, "Comparative study of different methods for estimating weibull parameters: A case study on jeju island, south korea," *Energies*, vol. 11, 2018. [Online]. Available: <https://doi.org/10.3390/en11020356>
- [319] S. Varricchio, N. Martins, and L. Garcia Lima, "A newton-raphson method based on eigenvalue sensitivities to improve harmonic voltage performance,"

- IEEE Transactions on Power Delivery*, vol. 18, 01 2003. [Online]. Available: <https://ieeexplore.ieee.org/document/1159940>
- [320] S. Varricchio and N. Martins, “Filter design using a newton-raphson method based on eigenvalue sensitivity,” in *IEEE 2000 Power Engineering Society Summer Meeting - Seattle, WA, USA (16-20 July 2000)*, (Cat. No.00CH37134), vol. 2, 2000. [Online]. Available: <https://ieeexplore.ieee.org/document/867470>
- [321] M. Van Valkenburg, *Network Analysis*. Prentice Hall, Inc, 1959, vol. 6.
- [322] S. Varricchio, N. Martins, T. L. Leonardo, and C. J. Sandoval, “Studying harmonic problems using a descriptor system approach,” in *IPST 99 International Conference on Power Systems Transients, June 20-24, 1999, Budapest, Hungary*, 1999.
- [323] S. Varricchio, S. Gomes, and N. Martins, “Modal analysis of industrial system harmonics using the s-domain approach,” *IEEE Transactions on Power Delivery*, vol. 19, 07 2004. [Online]. Available: <https://ieeexplore.ieee.org/document/1308350>
- [324] N. P. C. Gomes, S.; Martins, “Modal analysis applied to s-domain models of ac networks,” in *IEEE 2001 Winter Meeting of the IEEE Power Engineering Society - Columbus, OH, USA (28 Jan.-1 Feb. 2001)* (Cat. No.01CH37194), vol. 3, 2001. [Online]. Available: <https://ieeexplore.ieee.org/document/4077113>
- [325] Y. Cui and X. Wang, “Modal frequency sensitivity for power system harmonic resonance analysis,” *IEEE Transactions on Power Delivery*, vol. 27, 2012. [Online]. Available: <https://ieeexplore.ieee.org/document/4077113>
- [326] K. G. C. C. Rauma, Kalle; Md Hasan, “Resonance analysis of a wind power plant with modal approach,” in *IEEE-2012, IEEE 21st International Symposium on Industrial Electronics (ISIE) - Hangzhou, China (2012.05.28-2012.05.31)*, 2012. [Online]. Available: <https://ieeexplore.ieee.org/document/6237408>
- [327] E. H. L. Aarts and J. Korst, *Simulated Annealing and Boltzmann Machines: A Stochastic Approach to Combinatorial Optimization and Neural Computing*, 1st ed. Wiley, 1989.
- [328] S. Kirkpatrick, C. D. Gelatt, and M. P. Vecchi, “Optimization by simulated annealing,” *Science*, vol. 220, 1983.

- [329] A. Lagana, M. L. Gavrilova, V. Kumar, Y. Mun, C. J. K. Tan, and O. Gervasi, *An Efficient Simple Cooling Schedule for Simulated Annealing*, 2004, vol. 3045.
- [330] V. Laarhoven, P. J. M., and E. H. L. a. Aarts, *Simulated Annealing: Theory and Applications*, 1st ed., ser. Mathematics and Its Applications 37. Springer Netherlands, 1987.
- [331] J. M. Thompson and K. A. Dowsland, "Variants of simulated annealing for the examination timetabling problem," *Annals of Operations Research*, vol. 63, 1996.
- [332] B. Luke, *Practical Considerations for Simulated Annealing Implementation*, 1st ed., ser. Simulated Annealing. IntechOpen, 2005.
- [333] M. Locatelli, "Convergence of a simulated annealing algorithm for continuous global optimization," *Journal of Global Optimization*, vol. 18, 11 2000.
- [334] J. C. Das, *Power System Harmonics and Passive Filter Designs*, 1st ed., ser. IEEE Press Series on Power Engineering. Wiley-IEEE Press, 2015.
- [335] "Power quality and integration of wind farms in weak grids in india," in *Ris National Laboratory, Roskilde, April 2000*.
- [336] F. Blaabjerg, Z. Chen, and S. Kjaer, "Power electronics as efficient interface in dispersed power generation systems," *IEEE Transactions on Power Electronics*, vol. 19, 2004.
- [337] M. Ali, B. Wu, and R. Dougal, "An overview of smes applications in power and energy systems," *IEEE Transactions on Sustainable Energy*, vol. 1, 2010.
- [338] N. Flourentzou and G. Agelidis, V.G.and Demetriades, "Vsc-based hvdc power transmission systems: An overview," *IEEE Transactions on Power Electronics*, vol. 24, 2009.
- [339] X. Jiang, X. Fang, J. Chow, E. Edris, A. A.and Uzunovic, M. Parisi, and L. Hopkins, "A novel approach for modeling voltage-sourced converter-based facts controllers," *IEEE Transactions on Power Delivery*, vol. 23, 10 2008.
- [340] R. Middlebrook, "Input filter considerations in design and application of switching regulators," in *IEEE Ind. Appl. Soc. Annu. Meet, 1976*, 1976, pp. 366–382.

- [341] F. Freijedo, A. Yepes, O. Lopez, A. Vidal, and J. Doval-Gandoy, "Three-phase pll's with fast postfault retracking and steady-state rejection of voltage unbalance and harmonics by means of lead compensation," *IEEE Transactions on Power Electronics*, vol. 26, 2011.
- [342] M. R. P. Fei Wang; Duarte, J.L.; Hendrix, "Modeling and analysis of grid harmonic distortion impact of aggregated dg inverters," *IEEE Transactions on Power Electronics*, vol. 26, 2011.
- [343] R. Beres, X. Wang, F. Blaabjerg, M. Liserre, and C. Bak, "Optimal design of high-order passive-damped filters for grid-connected applications," *IEEE Transactions on Power Electronics*, 2015.
- [344] S. Jian, "Small-signal methods for ac distributed power systemsa review," *IEEE Transactions on Power Electronics*, vol. 24, 11 2009.
- [345] J. Jiao and R. M. Nelms, "Regulating output impedance using a pi controller to improve the stability of a single phase inverter under weak grid," in *IEEE 16th International Conference on Environment and Electrical Engineering (EEEIC) - Florence, Italy (2016.6.7-2016.6.10)*, 2016.
- [346] M. Yang, Wen; Wang, "Impedance modeling and output impedance coupling analysis of three-phase grid-connected inverters," in *IEEE International Power Electronics and Application Conference and Exposition (PEAC) - Shenzhen (2018.11.4-2018.11.7)*, 2018.
- [347] Q.-C. Zhong and Y. Zeng, "Control of inverters via a virtual capacitor to achieve capacitive output impedance," *IEEE Transactions on Power Electronics*, vol. 29, 10 2014.
- [348] Y. He, C.-t. Lai, S.-h. Chung, X. Zhang, and W. Wu, "Use of series negative impedance to cancel the effect of equivalent grid impedance on the grid-connected inverter stability in the dpgs," in *IEEE Applied Power Electronics Conference and Exposition (APEC) - San Antonio, TX, USA (2018.3.4-2018.3.8)*, 2018.
- [349] Q.-C. Zhong and Y. Zeng, "Universal droop control of inverters with different types of output impedance," *IEEE Access*, 2016.

- [350] T. Messo, R. Luhtala, A. Aapro, and T. Roinila, "Accurate impedance model of a grid-connected inverter for small-signal stability assessment in high-impedance grids," *IEEJ Journal of Industry Applications*, vol. 8, 5 2019.
- [351] P. Ling, P. Zhang, and C. Guo, "An impedance reshaping control strategy to enhance adaptability to grid for grid-connected inverters," in *China International Conference on Electricity Distribution (CICED)*, 2018.
- [352] "Ieee recommended practices and requirements for harmonic control in electrical power systems," Institute of Electrical and Electronic Engineers, Standard, 1992.
- [353] P. Daly and J. Morrison, "Understanding the potential benefits of distributed generation on power delivery systems," in *IEEE Bologna Power Tech Conference (June 23-26, 2003)*, Bologna, Italy, 2003.
- [354] C. Borges and D. M. Falcon, "Impact of distributed generation allocation and sizing on reliability, losses and voltage profile," in *IEEE Bologna Power Tech Conference Proceedings (June 23-26, 2003)*, Bologna, Italy, 2003.
- [355] W. Xiao, W. Dunford, and A. Capel, "A novel modeling method for photovoltaic cells," in *IEEE 35th Annual Power Electronics Specialists Conference - Aachen, Germany (20-25 June 2004)*, 2004.
- [356] I. H. Altas and A. Sharaf, "A photovoltaic array simulation model for matlab-simulink gui environment," in *International Conference on Clean Electrical Power - Capri, Italy (2007.05.21-2007.05.23)*, 2007.
- [357] M. Villalva, J. Gazoli, and E. Filho, "Comprehensive approach to modeling and simulation of photovoltaic arrays," *IEEE Transactions on Power Electronics*, vol. 24, 2009.
- [358] W. Zhang, W. Li, M. Zhao, and X. Liu, "Simulation of active power filter with one-cycle control under unipolar operation by pscad/emtsc," 2011.
- [359] M. Ropp and S. Gonzalez, "Development of a matlab/simulink model of a single-phase grid-connected photovoltaic system," *IEEE Transactions on Energy Conversion*, vol. 24, 2009.

- [360] R. Dugan, *Electrical Power Systems Quality*, 2nd ed. McGraw-Hill, 2004.
- [361] P. Dahono, A. Purwadi, and Qamaruzzaman, “An lc filter design method for single-phase pwm inverters,” in *International Conference on Power Electronics and Drive Systems, PEDS 95 - Singapore (21-24 Feb. 1995)*, 1995.
- [362] A. Al-Abduallah, A. Iqbal, A.-A. Al-Hamadi, K. Alawi, and M. Saleh, “Five-phase induction motor drive system with inverter output lc filter,” in *7th IEEE GCC Conference and Exhibition (GCC) - Doha, Qatar (2013.11.17-2013.11.20)*, 2013.
- [363] N. Li, N. Zhi, H. Zhang, Y. Wang, and Z. Wang, “A novel output lc filter design method of high power three-level npc converter,” in *IEEE International Power Electronics and Application Conference and Exposition (PEAC) - Shanghai, China (2014.11.5-2014.11.8)*, 2014.
- [364] Y. Xiao, J. Zhao, and M. Shijie, “Theory for the design of c-type filter,” in *11th International Conference on Harmonics and Quality of Power - Lake Placid, NY, USA (12-15 Sept. 2004)*, 2004.
- [365] *Power Electronics: Converters, Applications, and Design, Third edition*, 3rd ed. John Wiley & Sons, Inc., 2002.
- [366] Z. W. Wang, C. Shen, and F. Liu, “Probabilistic analysis of small signal stability for power systems with high penetration of wind generation,” *IEEE Transactions on Sustainable Energy*, 2016.
- [367] H. Chavez, R. Baldick, and S. Sharma, “Regulation adequacy analysis under high wind penetration scenarios in ercot nodal,” *IEEE Transactions on Sustainable Energy*, vol. 3, pp. 743–750, 10 2012.